

Отчет о суточных параметрах  
(01.08.2022 0:00:00 - 31.08.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 23 А (4 МКД УК "Заречная")  
Прибор: ИМ2300 А-Е Заводской номер: СА536  
Точка измерения: Узел 1; Ресурс: ТС

Подача:  
Обратка:  
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:  
ПРИМ SN 10292  
ПРИМ SN 10293

Датчик температуры:  
КТПТР-01 SN 4274  
КТПТР-01 SN 4274 А

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.08.2022	20.20	19.99	0.21	0.00	0.00	---	0.000	0.0	24.0
02.08.2022	20.30	20.08	0.22	0.00	0.00	---	0.000	0.0	24.0
03.08.2022	20.31	20.10	0.21	0.00	0.00	---	0.000	0.0	24.0
04.08.2022	20.28	20.07	0.20	0.00	0.00	---	0.000	0.0	24.0
05.08.2022	20.28	20.07	0.20	0.00	0.00	---	0.000	0.0	24.0
06.08.2022	20.29	20.08	0.21	0.00	0.00	---	0.000	0.0	24.0
07.08.2022	20.36	20.14	0.22	0.00	0.00	---	0.000	0.0	24.0
08.08.2022	20.48	20.24	0.24	0.00	0.00	---	0.000	0.0	24.0
09.08.2022	20.61	20.35	0.25	0.00	0.00	---	0.000	0.0	24.0
10.08.2022	20.73	20.46	0.27	0.00	0.00	---	0.000	0.0	24.0
11.08.2022	20.84	20.57	0.27	0.00	0.00	---	0.000	0.0	24.0
12.08.2022	20.74	20.53	0.21	0.00	0.00	---	0.000	0.0	24.0
13.08.2022	20.52	20.35	0.17	0.00	0.00	---	0.000	0.0	24.0
14.08.2022	20.47	20.31	0.15	0.00	0.00	---	0.000	0.0	24.0
15.08.2022	20.25	20.11	0.14	0.00	0.00	---	0.000	0.0	24.0
16.08.2022	20.16	20.03	0.13	0.00	0.00	---	0.000	0.0	24.0
17.08.2022	20.13	19.99	0.14	0.00	0.00	---	0.000	0.0	24.0
18.08.2022	20.09	19.86	0.23	0.00	0.00	---	0.000	0.0	24.0
19.08.2022	19.91	19.71	0.20	0.00	0.00	---	0.000	0.0	24.0
20.08.2022	19.63	19.46	0.17	0.00	0.00	---	0.000	0.0	24.0
21.08.2022	19.46	19.32	0.14	0.00	0.00	---	0.000	0.0	24.0
22.08.2022	19.58	19.41	0.17	0.00	0.00	---	0.000	0.0	24.0
23.08.2022	19.80	19.55	0.26	0.00	0.00	---	0.000	0.0	24.0
24.08.2022	19.82	19.56	0.27	0.00	0.00	---	0.000	0.0	24.0
25.08.2022	19.91	19.63	0.28	0.00	0.00	---	0.000	0.0	24.0
26.08.2022	20.04	19.74	0.30	0.00	0.00	---	0.000	0.0	24.0
27.08.2022	20.16	19.85	0.31	0.00	0.00	---	0.000	0.0	24.0
28.08.2022	20.18	19.91	0.27	0.00	0.00	---	0.000	0.0	24.0
29.08.2022	20.09	19.83	0.26	0.00	0.00	---	0.000	0.0	24.0
30.08.2022	20.20	19.93	0.27	0.00	0.00	---	0.000	0.0	24.0
31.08.2022	20.30	20.02	0.28	0.00	0.00	---	0.000	0.0	24.0
Средние:	20.20	19.98	0.22	---	---	0.00	---	---	---
Итого:	---	---	---	0.00	0.00	---	0.000	0.0	744.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.07.2022	1256.08	1279.85	45.772	1548.4	3604.9
31.08.2022	1256.08	1279.85	45.772	1548.4	4348.9
Итого:	0.00	0.00	0.000	0.0	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.09.2022 0:00:00 - 08.10.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 23 А (4 МКД УК "Заречная")  
Прибор: ИМ2300 А-Е Заводской номер: СА536  
Точка измерения: Узел 1; Ресурс: ТС

Подача:  
Обратка:  
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:  
ПРИМ SN 10292  
ПРИМ SN 10293

Датчик температуры:  
КТПТР-01 SN 4274  
КТПТР-01 SN 4274 А

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.09.2022	20.39	20.10	0.29	0.00	0.00	0.00	0.000	0.0	24.0
02.09.2022	20.39	20.12	0.27	0.00	0.00	0.00	0.000	0.0	24.0
03.09.2022	20.35	20.10	0.24	0.00	0.00	0.00	0.000	0.1	24.0
04.09.2022	19.92	19.71	0.21	0.00	0.00	0.00	0.000	0.0	24.0
05.09.2022	19.47	19.29	0.17	0.00	0.00	0.00	0.000	0.0	24.0
06.09.2022	19.11	18.98	0.13	0.00	0.00	0.00	0.000	0.0	24.0
07.09.2022	18.91	18.81	0.10	0.00	0.00	---	0.000	0.0	24.0
08.09.2022	18.67	18.58	0.09	0.00	0.00	0.00	0.000	0.0	24.0
09.09.2022	18.51	18.42	0.09	0.00	0.00	0.00	0.000	0.0	24.0
10.09.2022	18.34	18.26	0.08	0.00	0.00	0.00	0.000	0.1	24.0
11.09.2022	18.09	18.04	0.06	0.00	0.00	0.00	0.000	0.0	24.0
12.09.2022	17.97	17.92	0.05	0.00	0.00	0.00	0.000	0.0	24.0
13.09.2022	17.89	17.83	0.06	0.00	0.00	0.00	0.000	0.0	24.0
14.09.2022	17.83	17.78	0.05	0.00	0.00	0.00	0.000	0.0	24.0
15.09.2022	17.82	17.76	0.06	0.00	0.00	---	0.000	0.0	24.0
16.09.2022	17.86	17.79	0.07	0.00	0.00	---	0.000	0.0	24.0
17.09.2022	17.95	17.84	0.11	0.00	0.00	---	0.000	0.0	24.0
18.09.2022	18.00	17.89	0.11	0.00	0.00	---	0.000	0.0	24.0
19.09.2022	18.04	17.92	0.11	0.00	0.00	---	0.000	0.0	24.0
20.09.2022	18.10	17.97	0.12	0.00	0.00	---	0.000	0.0	24.0
21.09.2022	18.23	18.10	0.13	0.00	0.00	---	0.000	0.0	24.0
22.09.2022	44.81	30.21	14.60	13.82	13.99	-1.19	0.357	13.5	24.0
23.09.2022	62.31	38.97	23.34	22.81	23.06	-1.07	0.535	24.0	24.0
24.09.2022	68.17	44.06	24.11	27.63	27.96	-1.17	0.665	24.0	24.0
25.09.2022	65.12	43.67	21.45	28.59	28.89	-1.03	0.615	23.5	24.0
26.09.2022	67.59	45.19	22.40	29.96	30.29	-1.09	0.669	24.0	24.0
27.09.2022	66.83	43.01	23.82	26.24	26.54	-1.14	0.623	24.0	24.0
28.09.2022	68.75	48.10	20.65	37.90	38.29	-1.03	0.778	24.0	24.0
29.09.2022	70.53	48.81	21.72	37.41	37.82	-1.11	0.811	24.0	24.0
30.09.2022	69.63	47.37	22.26	34.66	35.05	-1.12	0.770	24.0	24.0
01.10.2022	70.00	47.15	22.85	33.51	33.90	-1.15	0.764	24.0	24.0
02.10.2022	69.37	47.09	22.28	33.71	34.09	-1.12	0.750	24.0	24.0
03.10.2022	70.19	48.84	21.35	36.38	36.78	-1.09	0.776	24.0	24.0
04.10.2022	70.41	49.52	20.89	37.07	37.47	-1.07	0.773	24.0	24.0
05.10.2022	70.18	49.66	20.52	36.80	37.18	-1.05	0.754	24.0	24.0
06.10.2022	69.54	48.57	20.97	34.67	35.05	-1.07	0.727	24.0	24.0
07.10.2022	69.38	48.40	20.98	34.48	34.84	-1.06	0.722	24.0	24.0
08.10.2022	69.75	49.66	20.09	36.94	37.32	-1.03	0.743	24.0	24.0
Средние:	40.38	30.72	9.65	---	---	-0.49	---	---	---
Итого:	---	---	---	542.60	548.53	---	11.832	397.5	912.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.08.2022	1256.08	1279.85	45.772	1548.4	4348.9
08.10.2022	1798.68	1828.39	57.604	1945.8	5260.9
Итого:	542.60	548.53	11.832	397.5	912.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.10.2022 0:00:00 - 31.10.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 23 А (4 МКД УК "Заречная")  
Прибор: ИМ2300 А-Е Заводской номер: СА536  
Точка измерения: Узел 1; Ресурс: ТС

Подача:  
Обратка:  
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:  
ПРИМ SN 10292  
ПРИМ SN 10293

Датчик температуры:  
КТПТР-01 SN 4274  
КТПТР-01 SN 4274 А

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.10.2022	70.00	47.15	22.85	33.51	33.90	-1.15	0.764	24.0	24.0
02.10.2022	69.37	47.09	22.28	33.71	34.09	-1.12	0.750	24.0	24.0
03.10.2022	70.19	48.84	21.35	36.38	36.78	-1.09	0.776	24.0	24.0
04.10.2022	70.41	49.52	20.89	37.07	37.47	-1.07	0.773	24.0	24.0
05.10.2022	70.18	49.66	20.52	36.80	37.18	-1.05	0.754	24.0	24.0
06.10.2022	69.54	48.57	20.97	34.67	35.05	-1.07	0.727	24.0	24.0
07.10.2022	69.38	48.40	20.98	34.48	34.84	-1.06	0.722	24.0	24.0
08.10.2022	69.75	49.66	20.09	36.94	37.32	-1.03	0.743	24.0	24.0
09.10.2022	70.96	49.15	21.81	34.94	35.34	-1.12	0.760	24.0	24.0
10.10.2022	70.73	49.73	20.99	36.36	36.76	-1.08	0.762	24.0	24.0
11.10.2022	70.15	49.39	20.77	35.44	35.82	-1.06	0.735	23.7	24.0
12.10.2022	71.20	48.60	22.60	32.88	33.26	-1.16	0.742	24.0	24.0
13.10.2022	70.04	47.46	22.58	31.61	31.97	-1.14	0.713	24.0	24.0
14.10.2022	70.30	49.35	20.95	35.81	36.19	-1.07	0.748	24.0	24.0
15.10.2022	70.09	48.37	21.72	33.32	33.68	-1.10	0.722	24.0	24.0
16.10.2022	70.68	48.16	22.52	32.62	32.99	-1.15	0.734	24.0	24.0
17.10.2022	69.82	46.78	23.04	30.32	30.67	-1.16	0.697	24.0	24.0
18.10.2022	70.03	47.27	22.77	31.47	31.83	-1.15	0.716	24.0	24.0
19.10.2022	69.93	46.97	22.97	31.20	31.56	-1.15	0.715	24.0	24.0
20.10.2022	69.68	46.13	23.55	29.46	29.81	-1.17	0.692	24.0	24.0
21.10.2022	69.33	44.45	24.88	27.14	27.47	-1.22	0.674	24.0	24.0
22.10.2022	70.12	45.74	24.38	29.46	29.82	-1.22	0.717	24.0	24.0
23.10.2022	69.54	45.36	24.18	30.21	30.57	-1.20	0.729	24.0	24.0
24.10.2022	71.73	47.53	24.20	33.16	33.57	-1.23	0.801	24.0	24.0
25.10.2022	70.77	47.28	23.48	33.31	33.70	-1.19	0.780	24.0	24.0
26.10.2022	69.46	45.08	24.38	29.62	29.98	-1.20	0.721	24.0	24.0
27.10.2022	69.97	44.48	25.48	28.11	28.47	-1.26	0.715	24.0	24.0
28.10.2022	69.15	41.80	27.34	24.69	25.02	-1.30	0.665	24.0	24.0
29.10.2022	69.28	44.81	24.47	30.64	31.01	-1.21	0.749	24.0	24.0
30.10.2022	69.07	44.96	24.11	30.86	31.23	-1.19	0.743	24.0	24.0
31.10.2022	69.17	44.85	24.32	30.41	30.78	-1.20	0.738	24.0	24.0
Средние:	70.00	47.18	22.82	---	---	-1.15	---	---	---
Итого:	---	---	---	1006.58	1018.14	---	22.778	743.7	744.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
30.09.2022	1515.12	1541.76	51.596	1753.8	5068.9
31.10.2022	2521.70	2559.89	74.374	2497.5	5812.9
Итого:	1006.58	1018.14	22.778	743.7	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.11.2022 0:00:00 - 30.11.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 23 А (4 МКД УК "Заречная")  
Прибор: ИМ2300 А-Е Заводской номер: СА536  
Точка измерения: Узел 1; Ресурс: ТС

Подача: Счетчик воды:  
Обратка: ПРИМ SN 10292  
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Датчик температуры:  
КТПТР-01 SN 4274  
КТПТР-01 SN 4274 А

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.11.2022	68.85	45.40	23.44	31.44	31.81	-1.16	0.736	24.0	24.0
02.11.2022	68.73	45.60	23.13	32.16	32.53	-1.14	0.743	24.0	24.0
03.11.2022	69.09	47.26	21.83	35.59	35.98	-1.09	0.775	24.0	24.0
04.11.2022	68.93	46.80	22.12	34.44	34.83	-1.10	0.761	24.0	24.0
05.11.2022	70.43	46.83	23.60	33.12	33.51	-1.19	0.780	24.0	24.0
06.11.2022	70.93	46.65	24.28	32.44	32.84	-1.23	0.787	24.0	24.0
07.11.2022	70.18	45.67	24.51	31.54	31.93	-1.22	0.772	24.0	24.0
08.11.2022	71.35	46.66	24.70	32.27	32.68	-1.25	0.796	24.0	24.0
09.11.2022	71.10	46.69	24.41	32.79	33.20	-1.23	0.799	24.0	24.0
10.11.2022	71.26	48.15	23.11	36.15	36.58	-1.18	0.833	24.0	24.0
11.11.2022	71.84	48.95	22.89	37.27	37.71	-1.18	0.851	24.0	24.0
12.11.2022	72.12	50.38	21.74	40.46	40.92	-1.13	0.878	24.0	24.0
13.11.2022	71.89	50.43	21.46	40.37	40.82	-1.12	0.865	24.0	24.0
14.11.2022	71.93	49.89	22.04	38.57	39.02	-1.14	0.848	24.0	24.0
15.11.2022	76.10	49.56	26.54	34.15	34.64	-1.41	0.904	24.0	24.0
16.11.2022	86.53	54.32	32.21	34.68	35.33	-1.87	1.118	24.0	24.0
17.11.2022	92.00	56.68	35.32	34.88	35.63	-2.13	1.233	24.0	24.0
18.11.2022	100.15	59.87	40.29	34.51	35.41	-2.57	1.393	24.0	24.0
19.11.2022	106.17	63.80	42.37	36.02	37.06	-2.83	1.531	24.0	24.0
20.11.2022	103.56	62.27	41.29	35.74	36.72	-2.71	1.479	24.0	24.0
21.11.2022	103.11	62.47	40.64	36.29	37.27	-2.66	1.478	24.0	24.0
22.11.2022	101.47	62.30	39.17	37.05	38.01	-2.54	1.455	24.0	24.0
23.11.2022	94.79	59.75	35.05	37.70	38.54	-2.18	1.323	24.0	24.0
24.11.2022	91.09	56.89	34.20	36.01	36.76	-2.06	1.232	24.0	24.0
25.11.2022	93.02	57.85	35.16	36.57	37.36	-2.15	1.287	24.0	24.0
26.11.2022	98.67	60.36	38.31	36.64	37.54	-2.44	1.406	24.0	24.0
27.11.2022	99.85	60.17	39.68	35.94	36.86	-2.53	1.429	24.0	24.0
28.11.2022	100.08	60.36	39.73	36.02	36.95	-2.54	1.434	24.0	24.0
29.11.2022	98.41	59.68	38.73	35.97	36.86	-2.45	1.395	24.0	24.0
30.11.2022	101.20	59.01	42.19	33.92	34.84	-2.70	1.434	24.0	24.0
Средние:	84.49	53.69	30.81	---	---	-1.80	---	---	---
Итого:	---	---	---	1060.72	1080.13	---	32.758	720.0	720.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.10.2022	2521.70	2559.89	74.374	2497.5	5812.9
30.11.2022	3582.41	3640.02	107.132	3217.5	6532.9
Итого:	1060.72	1080.13	32.758	720.0	720.0

Представитель абонента

Представитель энергоснабжающей организации