

Отчет о суточных параметрах ГВС
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	V1	M1	P1	Q1	Траб	NS	gNSCode
	°C	м3	т	кгс/см2	Гкал	ч		
01.09.2024	49.97	1.107	1.094	3.95	0.049	24.0		Ok
02.09.2024	49.00	1.141	1.128	3.95	0.050	24.0		Ok
03.09.2024	48.85	1.152	1.139	4.27	0.050	24.0		Ok
04.09.2024	50.60	1.546	1.527	3.84	0.070	24.0		Ok
05.09.2024	50.56	1.241	1.226	3.93	0.056	24.0		Ok
06.09.2024	51.50	1.578	1.558	4.16	0.072	24.0		Ok
07.09.2024	52.82	1.779	1.756	4.26	0.084	24.0		Ok
08.09.2024	50.61	1.179	1.165	4.07	0.053	24.0		Ok
09.09.2024	50.21	1.298	1.283	4.02	0.058	24.0		Ok
10.09.2024	51.54	1.341	1.324	4.02	0.062	24.0		Ok
11.09.2024	52.44	1.153	1.138	4.25	0.054	24.0		Ok
12.09.2024	51.59	1.414	1.396	4.17	0.065	24.0		Ok
13.09.2024	51.27	1.267	1.251	4.21	0.058	24.0		Ok
14.09.2024	51.98	1.462	1.443	4.28	0.068	24.0		Ok
15.09.2024	53.31	1.739	1.716	4.07	0.083	24.0		Ok
16.09.2024	54.53	1.461	1.441	4.03	0.071	24.0		Ok
17.09.2024	53.09	1.542	1.522	4.19	0.073	24.0		Ok
18.09.2024	52.67	1.457	1.438	4.18	0.069	24.0		Ok
19.09.2024	53.05	1.494	1.474	4.19	0.071	24.0		Ok
20.09.2024	52.55	1.286	1.269	4.24	0.060	24.0		Ok
21.09.2024	51.83	1.360	1.343	4.16	0.063	24.0		Ok
22.09.2024	52.61	1.583	1.562	3.71	0.074	24.0		Ok
23.09.2024	50.74	1.269	1.254	3.80	0.057	23.2		Ok
24.09.2024	51.98	1.415	1.397	4.12	0.066	24.0		Ok
25.09.2024	51.21	1.345	1.328	4.21	0.061	24.0		Ok
26.09.2024	52.23	1.496	1.477	4.16	0.070	24.0		Ok
27.09.2024	53.41	1.672	1.650	4.24	0.080	24.0		Ok
28.09.2024	54.07	1.833	1.808	4.06	0.089	24.0		Ok
29.09.2024	51.52	1.827	1.804	3.78	0.084	24.0		Ok
30.09.2024	52.19	1.415	1.397	4.21	0.066	24.0		Ok
Средние:	51.80	---	---	4.09	---	---		
Итого:	---	42.852	42.311	---	1.984	719.2		

Дата	V1	M1	Q1	Траб
	м3	т	Гкал	ч
31.08.2024	1568.898	1547.433	75.707	24715.7
30.09.2024	1611.750	1589.744	77.692	25434.9
Итого:	42.852	42.311	1.984	719.2

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: ВКТ-7 Заводской номер: 00115028
Точка измерения: ТВ1; Ресурс: ТС

Подача:
Обратка:
Схема измерений: Закрытая система отопления (Схема 3)

Счетчик воды:
ПРЭМ SN 334995
ПРЭМ SN 333703

Датчик температуры:
КТСП-Н SN 32048г
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Мг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.09.2024	24.14	22.39	1.75	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
02.09.2024	24.67	23.03	1.64	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
03.09.2024	25.45	23.95	1.50	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
04.09.2024	24.40	22.76	1.64	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
05.09.2024	24.95	23.25	1.70	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
06.09.2024	25.48	24.02	1.46	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
07.09.2024	26.51	25.02	1.49	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
08.09.2024	26.41	25.06	1.35	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
09.09.2024	26.93	25.58	1.35	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
10.09.2024	26.99	25.64	1.35	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
11.09.2024	27.21	25.80	1.41	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
12.09.2024	26.94	25.58	1.36	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
13.09.2024	27.00	25.62	1.38	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
14.09.2024	27.25	25.90	1.35	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
15.09.2024	27.48	26.10	1.38	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
16.09.2024	27.66	26.25	1.41	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
17.09.2024	27.59	26.19	1.40	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
18.09.2024	27.58	26.15	1.43	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
19.09.2024	27.17	25.84	1.33	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
20.09.2024	26.75	25.41	1.34	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
21.09.2024	26.23	24.90	1.33	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
22.09.2024	25.71	24.13	1.58	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
23.09.2024	23.81	21.98	1.83	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
24.09.2024	24.35	22.78	1.57	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
25.09.2024	25.03	23.41	1.62	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
26.09.2024	25.45	23.88	1.57	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
27.09.2024	25.72	24.22	1.50	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
28.09.2024	25.61	24.20	1.41	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
29.09.2024	26.43	24.91	1.52	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
30.09.2024	65.68	45.24	20.44	12.07	11.67	3.37	11.85	11.57	2.39	0.28	9.00	5.00	0.242	24.0	0.0	*
Средние:	27.42	25.31	2.11	---	---	0.11	---	---	0.08	---	9.00	5.00	---	---	---	
Итого:	---	---	---	12.07	11.67	---	11.85	11.57	---	0.28	---	---	0.242	720.0	0.0	

Дата	V1	V2	M1	M2	Мг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
31.08.2024	4350.38	4467.95	4230.78	4421.91	-191.13	146.922	14675.0	1.0
30.09.2024	4362.45	4479.62	4242.63	4433.48	-190.85	147.164	15395.0	1.0
Итого:	12.07	11.67	11.85	11.57	0.28	0.242	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации