

Отчет о суточных параметрах
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Чистопольская ул, д. 5 (ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 41264123
Точка измерения: Подсистема 1; Ресурс: TC

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	t2 °C	dt °C	V1 м3	V2 м3	M1 т	M2 т	P1 кгс/см2	P2 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.09.2024	17.82	17.46	0.37	0.000	0.000	0.000	0.000	2.24	2.31	0.000	24.0	*	min; HC
02.09.2024	17.79	17.57	0.23	0.000	0.001	0.000	0.001	2.36	2.44	0.000	24.0	*	min; HC G; H
03.09.2024	17.72	17.58	0.14	0.000	0.005	0.000	0.005	2.69	2.68	0.000	24.0	*	min; HC G; H
04.09.2024	17.63	17.40	0.23	0.000	0.000	0.000	0.000	2.44	2.52	0.000	24.0	*	min; HC
05.09.2024	17.59	17.40	0.20	0.000	0.000	0.000	0.000	2.37	2.45	0.000	24.0	*	min; HC
06.09.2024	17.40	17.16	0.24	0.000	0.000	0.000	0.000	2.32	2.40	0.000	24.0	*	min; HC
07.09.2024	17.70	17.56	0.14	0.000	0.000	0.000	0.000	2.29	2.37	0.000	24.0	*	min; HC
08.09.2024	17.83	17.66	0.17	0.000	0.000	0.000	0.000	2.25	2.33	0.000	24.0	*	min; HC
09.09.2024	18.01	17.84	0.17	0.000	0.000	0.000	0.000	2.23	2.31	0.000	24.0	*	min; HC
10.09.2024	18.18	18.00	0.18	0.000	0.000	0.000	0.000	2.21	2.28	0.000	24.0	*	min; HC
11.09.2024	18.26	18.07	0.19	0.000	0.000	0.000	0.000	2.18	2.26	0.000	24.0	*	min; HC
12.09.2024	18.23	18.05	0.18	0.000	0.000	0.000	0.000	2.16	2.24	0.000	24.0	*	min; HC
13.09.2024	18.16	17.96	0.20	0.000	0.000	0.000	0.000	2.14	2.22	0.000	24.0	*	min; HC
14.09.2024	18.23	18.05	0.18	0.000	0.000	0.000	0.000	2.13	2.21	0.000	24.0	*	min; HC
15.09.2024	18.31	18.11	0.20	0.000	0.000	0.000	0.000	2.11	2.19	0.000	24.0	*	min; HC
16.09.2024	18.31	18.10	0.21	0.000	0.000	0.000	0.000	2.09	2.17	0.000	24.0	*	min; HC
17.09.2024	18.37	18.15	0.22	0.000	0.000	0.000	0.000	2.08	2.16	0.000	24.0	*	min; HC
18.09.2024	18.36	18.12	0.24	0.000	0.000	0.000	0.000	2.07	2.15	0.000	24.0	*	min; HC
19.09.2024	18.38	18.16	0.22	0.000	0.000	0.000	0.000	2.07	2.14	0.000	24.0	*	min; HC
20.09.2024	18.20	17.95	0.25	0.000	0.000	0.000	0.000	2.06	2.13	0.000	24.0	*	min; HC
21.09.2024	17.73	17.43	0.29	0.000	0.000	0.000	0.000	2.04	2.12	0.000	24.0	*	min; HC
22.09.2024	16.94	16.66	0.29	0.000	0.000	0.000	0.000	2.02	2.09	0.000	24.0	*	min; HC
23.09.2024	15.50	15.11	0.39	0.001	0.004	0.001	0.004	2.10	2.11	0.000	24.0	*	min; HC G; H
24.09.2024	33.72	22.39	11.34	16.445	15.968	16.171	15.895	3.68	3.16	0.434	24.0	*	min; HC G; H
25.09.2024	62.31	34.42	27.89	40.162	40.213	39.452	40.010	6.16	4.83	1.101	24.0		Ok
26.09.2024	64.19	36.47	27.71	44.306	44.315	43.478	44.058	6.57	4.92	1.205	24.0		Ok
27.09.2024	48.26	31.71	16.55	25.071	25.114	24.623	24.976	4.30	3.49	0.666	24.0	*	min; HC G; H
28.09.2024	17.62	17.51	0.11	0.000	0.000	0.000	0.000	1.09	1.17	0.000	24.0	*	min; HC
29.09.2024	16.68	16.71	-0.02	0.000	0.000	0.000	0.000	0.70	0.78	0.000	24.0	*	min; HC
30.09.2024	22.91	22.57	0.35	3.147	2.541	3.114	2.517	1.33	1.31	0.015	24.0	*	min; HC G; H
Средние:	22.55	19.58	2.97	---	---	---	---	2.48	2.40	---	---		
Итого:	---	---	---	129.133	128.161	126.839	127.465	---	---	3.421	720.0		

Дата	V1 м3	V2 м3	M1 т	M2 т	Q1 Гкал	Траб ч
31.08.2024	7.888	15.115	7.886	15.110	0.002	2290.1
30.09.2024	137.021	143.276	134.724	142.576	3.423	3010.1
Итого:	129.133	128.161	126.839	127.465	3.421	720.0

Представитель абонента

Представитель энергоснабжающей организации