

Отчет о суточных параметрах ГВС
(01.04.2026 0:00:00 - 30.04.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.04.2026	53.42	2.020	1.993	3.82	0.096	24.0		Ok
02.04.2026	53.09	2.347	2.316	3.97	0.111	24.0		Ok
03.04.2026	50.77	1.570	1.551	3.99	0.071	24.0		Ok
04.04.2026	52.46	1.752	1.729	3.86	0.082	24.0		Ok
05.04.2026	52.37	1.996	1.970	3.53	0.093	24.0		Ok
06.04.2026	53.27	2.454	2.422	3.87	0.117	24.0		Ok
07.04.2026	52.83	1.879	1.855	3.98	0.089	24.0		Ok
08.04.2026	53.42	2.110	2.082	3.89	0.101	24.0		Ok
09.04.2026	52.10	1.847	1.824	3.89	0.086	24.0		Ok
10.04.2026	53.62	2.260	2.230	3.98	0.108	24.0		Ok
11.04.2026	52.59	2.029	2.003	3.77	0.095	24.0		Ok
12.04.2026	52.69	1.963	1.937	3.65	0.092	24.0		Ok
13.04.2026	53.28	2.443	2.411	3.93	0.116	24.0		Ok
14.04.2026	52.68	1.751	1.728	4.06	0.082	24.0		Ok
15.04.2026	52.98	1.653	1.631	3.92	0.078	24.0		Ok
16.04.2026	53.33	1.512	1.492	3.94	0.072	24.0		Ok
17.04.2026	53.26	2.072	2.045	3.97	0.099	24.0		Ok
18.04.2026	52.63	1.521	1.501	3.93	0.071	24.0		Ok
19.04.2026	51.02	1.599	1.580	3.57	0.073	24.0		Ok
20.04.2026	52.10	1.886	1.862	3.90	0.088	24.0		Ok
21.04.2026	51.91	1.928	1.904	4.04	0.089	24.0		Ok
22.04.2026	52.67	2.147	2.119	3.89	0.101	24.0		Ok
23.04.2026	51.41	1.573	1.554	3.85	0.072	24.0		Ok
24.04.2026	51.42	1.572	1.553	3.06	0.072	24.0		Ok
25.04.2026	52.47	1.943	1.918	3.95	0.091	24.0		Ok
26.04.2026	50.25	1.422	1.405	3.81	0.064	24.0		Ok
27.04.2026	52.58	1.964	1.939	3.90	0.092	24.0		Ok
28.04.2026	52.09	1.735	1.713	4.04	0.081	24.0		Ok
29.04.2026	53.07	2.297	2.267	4.07	0.109	24.0		Ok
30.04.2026	52.29	1.697	1.675	4.12	0.079	24.0		Ok
Средние:	52.47	---	---	3.87	---	---		
Итого:	---	56.942	56.208	---	2.671	720.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.03.2026	2501.042	2467.435	119.654	38144.0
30.04.2026	2557.984	2523.643	122.326	38864.0
Итого:	56.942	56.208	2.671	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.04.2026 0:00:00 - 30.04.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Обратка: ПРЭМ SN 333703

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.04.2026	65.77	38.77	27.00	11.26	11.08	1.61	11.02	11.08	-0.54	-0.06	9.00	5.00	0.298	24.0	0.0	
02.04.2026	67.35	39.83	27.52	11.60	11.42	1.56	11.36	11.42	-0.53	-0.06	9.00	5.00	0.314	24.0	0.0	
03.04.2026	65.85	39.22	26.63	11.32	11.13	1.69	11.08	11.13	-0.45	-0.05	9.00	5.00	0.296	24.0	0.0	
04.04.2026	64.98	38.09	26.89	9.94	9.77	1.73	9.72	9.77	-0.51	-0.05	9.00	5.00	0.261	24.0	0.0	
05.04.2026	64.96	37.69	27.27	10.12	9.94	1.79	9.90	9.94	-0.40	-0.04	9.00	5.00	0.271	24.0	0.0	
06.04.2026	64.56	36.79	27.77	9.80	9.63	1.75	9.56	9.63	-0.73	-0.07	9.00	5.00	0.268	24.0	0.0	
07.04.2026	64.74	36.75	27.99	9.89	9.73	1.63	9.65	9.73	-0.83	-0.08	9.00	5.00	0.269	24.0	0.0	
08.04.2026	65.14	37.09	28.05	10.27	10.10	1.67	10.03	10.10	-0.70	-0.07	9.00	5.00	0.278	24.0	0.0	
09.04.2026	64.07	35.41	28.66	9.22	9.06	1.75	8.98	9.06	-0.89	-0.08	9.00	5.00	0.257	24.0	0.0	
10.04.2026	65.88	35.26	30.62	9.70	9.55	1.56	9.46	9.55	-0.95	-0.09	9.00	5.00	0.290	24.0	0.0	
11.04.2026	65.09	35.54	29.55	10.02	9.87	1.51	9.78	9.87	-0.92	-0.09	9.00	5.00	0.292	24.0	0.0	
12.04.2026	64.52	35.23	29.29	9.59	9.44	1.58	9.35	9.44	-0.96	-0.09	9.00	5.00	0.274	24.0	0.0	
13.04.2026	64.95	35.86	29.09	9.91	9.76	1.53	9.67	9.76	-0.93	-0.09	9.00	5.00	0.283	24.0	0.0	
14.04.2026	65.53	37.67	27.86	10.82	10.67	1.40	10.58	10.67	-0.85	-0.09	9.00	5.00	0.297	24.0	0.0	
15.04.2026	65.39	37.03	28.36	10.31	10.15	1.56	10.07	10.15	-0.79	-0.08	9.00	5.00	0.285	24.0	0.0	
16.04.2026	64.80	36.19	28.61	9.60	9.45	1.57	9.36	9.45	-0.96	-0.09	9.00	5.00	0.268	24.0	0.0	
17.04.2026	65.73	37.56	28.17	10.39	10.24	1.45	10.15	10.24	-0.88	-0.09	9.00	5.00	0.285	24.0	0.0	
18.04.2026	65.12	37.87	27.25	10.42	10.27	1.45	10.18	10.27	-0.88	-0.09	9.00	5.00	0.281	24.0	0.0	
19.04.2026	65.09	36.77	28.32	10.00	9.84	1.61	9.76	9.84	-0.82	-0.08	9.00	5.00	0.275	24.0	0.0	
20.04.2026	66.29	37.06	29.23	10.29	10.14	1.47	10.05	10.14	-0.89	-0.09	9.00	5.00	0.292	24.0	0.0	
21.04.2026	66.92	36.33	30.59	9.81	9.68	1.33	9.57	9.68	-1.14	-0.11	9.00	5.00	0.292	24.0	0.0	
22.04.2026	66.70	37.06	29.64	10.34	10.20	1.36	10.10	10.20	-0.99	-0.10	9.00	5.00	0.298	24.0	0.0	
23.04.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
24.04.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
25.04.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
26.04.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
27.04.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
28.04.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
29.04.2026	64.61	36.32	28.29	17.46	17.49	-0.17	17.01	17.49	-2.78	-0.48	---	---	0.597	39.0	0.0	*
30.04.2026	64.99	36.75	28.24	9.96	9.81	1.52	9.72	9.81	-0.92	-0.09	9.00	5.00	0.275	24.0	0.0	
Средние:	65.38	37.01	28.37	---	---	1.50	---	---	-0.88	---	9.00	5.00	---	---	---	
Итого:	---	---	---	252.04	248.42	---	246.11	248.42	---	-2.31	---	---	7.096	591.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.03.2026	11089.76	11097.08	10791.98	10988.88	-196.90	340.196	28523.0	1.0
30.04.2026	27.42	27.30	26.73	27.30	-0.57	0.872	63.0	0.0
Итого:	-11062.34	-11069.78	-10765.25	-10961.58	196.33	-339.324	-28460.0	-1.0

Представитель абонента

Представитель энергоснабжающей организации