

Отчет о суточных параметрах ГВС
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.03.2023	55.04	1.887	1.860	3.90	0.093	24.0		Ok
02.03.2023	54.66	1.971	1.944	3.95	0.096	24.0		Ok
03.03.2023	55.54	1.893	1.866	3.95	0.094	24.0		Ok
04.03.2023	55.29	1.681	1.657	3.87	0.083	24.0		Ok
05.03.2023	54.26	1.648	1.625	3.73	0.080	24.0	*	IC V; HC I
06.03.2023	55.31	1.946	1.918	3.85	0.096	24.0		Ok
07.03.2023	54.52	1.843	1.817	3.89	0.090	24.0		Ok
08.03.2023	54.56	1.846	1.820	3.73	0.090	24.0		Ok
09.03.2023	53.50	1.838	1.814	3.84	0.088	24.0		Ok
10.03.2023	55.12	2.636	2.599	3.96	0.130	24.0		Ok
11.03.2023	54.81	1.959	1.932	3.95	0.096	24.0		Ok
12.03.2023	54.69	2.195	2.164	3.75	0.107	24.0		Ok
13.03.2023	53.96	1.508	1.488	4.05	0.073	24.0		Ok
14.03.2023	55.00	2.372	2.339	4.04	0.117	24.0		Ok
15.03.2023	53.83	1.696	1.673	4.14	0.082	24.0		Ok
16.03.2023	54.93	1.953	1.926	4.08	0.096	24.0		Ok
17.03.2023	54.74	1.875	1.849	4.04	0.092	24.0		Ok
18.03.2023	55.04	2.452	2.418	4.00	0.121	24.0		Ok
19.03.2023	54.26	1.504	1.483	3.81	0.073	24.0		Ok
20.03.2023	53.83	1.698	1.675	3.99	0.082	24.0		Ok
21.03.2023	54.80	2.401	2.367	4.13	0.118	24.0		Ok
22.03.2023	54.52	1.865	1.839	4.01	0.091	24.0		Ok
23.03.2023	54.05	1.668	1.645	4.04	0.081	24.0		Ok
24.03.2023	53.90	1.413	1.394	4.06	0.068	24.0		Ok
25.03.2023	54.36	1.403	1.384	3.94	0.068	24.0		Ok
26.03.2023	53.87	1.399	1.380	3.75	0.067	24.0		Ok
27.03.2023	54.02	1.412	1.393	3.98	0.068	24.0		Ok
28.03.2023	54.30	1.535	1.514	3.88	0.075	24.0		Ok
29.03.2023	54.72	1.643	1.620	4.00	0.081	24.0		Ok
30.03.2023	53.04	1.407	1.389	3.89	0.067	24.0		Ok
31.03.2023	54.78	1.922	1.895	4.01	0.094	24.0		Ok
Средние:	54.49	---	---	3.94	---	---		
Итого:	---	56.469	55.686	---	2.758	744.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
28.02.2023	767.050	755.753	38.648	11515.7
31.03.2023	823.519	811.440	41.407	12259.7
Итого:	56.469	55.687	2.758	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: ВКТ-7 Заводской номер: 00115028
Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995
Обратка: ПРЭМ SN 333703
Схема измерений: Закрытая система отопления (Схема 3)

Датчик температуры:
КТСП-Н SN 32048г
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2023	76.90	42.81	34.09	12.98	13.14	-1.23	12.72	13.08	-2.79	-0.36	9.00	5.00	0.433	24.0	0.0	
02.03.2023	83.66	44.95	38.71	13.21	13.32	-0.83	12.84	13.20	-2.76	-0.36	9.00	5.00	0.497	24.0	0.0	
03.03.2023	91.82	49.23	42.59	14.34	14.39	-0.35	13.86	14.15	-2.07	-0.29	9.00	5.00	0.594	24.0	0.0	
04.03.2023	83.08	47.01	36.07	14.26	14.38	-0.84	13.84	14.16	-2.29	-0.32	9.00	5.00	0.498	24.0	0.0	
05.03.2023	72.94	41.93	31.01	12.52	12.72	-1.58	12.29	12.64	-2.81	-0.35	9.00	5.00	0.382	24.0	0.0	
06.03.2023	71.19	40.89	30.30	12.61	12.82	-1.65	12.37	12.82	-3.57	-0.45	9.00	5.00	0.375	24.0	0.0	
07.03.2023	69.90	40.60	29.30	12.90	13.13	-1.77	12.66	13.11	-3.49	-0.45	9.00	5.00	0.372	24.0	0.0	
08.03.2023	69.35	40.02	29.33	12.64	12.86	-1.73	12.40	12.86	-3.64	-0.46	9.00	5.00	0.361	24.0	0.0	
09.03.2023	64.81	36.46	28.35	9.93	10.16	-2.29	9.76	10.16	-4.02	-0.40	9.00	5.00	0.276	24.0	0.0	
10.03.2023	60.70	33.62	27.08	9.50	9.74	-2.49	9.31	9.74	-4.51	-0.43	9.00	5.00	0.253	24.0	0.0	
11.03.2023	68.95	39.22	29.73	12.67	12.90	-1.80	12.43	12.89	-3.63	-0.46	9.00	5.00	0.368	24.0	0.0	
12.03.2023	75.57	43.43	32.14	14.01	14.18	-1.21	13.69	13.98	-2.10	-0.29	9.00	5.00	0.441	24.0	0.0	
13.03.2023	68.57	41.57	27.00	13.50	13.75	-1.83	13.22	13.69	-3.49	-0.47	9.00	5.00	0.358	24.0	0.0	
14.03.2023	68.98	39.49	29.49	12.12	12.34	-1.80	11.88	12.34	-3.80	-0.46	9.00	5.00	0.351	24.0	0.0	
15.03.2023	67.53	38.60	28.93	11.38	11.61	-2.00	11.14	11.61	-4.13	-0.47	9.00	5.00	0.326	24.0	0.0	
16.03.2023	64.99	37.87	27.12	11.62	11.86	-2.04	11.38	11.86	-4.13	-0.48	9.00	5.00	0.310	24.0	0.0	
17.03.2023	65.90	39.90	26.00	13.02	13.27	-1.90	12.78	13.27	-3.76	-0.49	9.00	5.00	0.335	24.0	0.0	
18.03.2023	67.04	39.59	27.45	12.21	12.45	-1.95	11.97	12.45	-3.93	-0.48	9.00	5.00	0.328	24.0	0.0	
19.03.2023	74.99	42.89	32.10	13.40	13.58	-1.33	13.10	13.49	-2.93	-0.39	9.00	5.00	0.423	24.0	0.0	
20.03.2023	71.68	42.48	29.20	13.67	13.60	0.51	13.43	13.48	-0.37	-0.05	9.00	5.00	0.396	24.0	0.0	
21.03.2023	65.64	38.52	27.12	11.45	11.08	3.28	11.21	11.07	1.26	0.14	9.00	5.00	0.305	24.0	0.0	
22.03.2023	64.92	38.55	26.37	12.02	11.65	3.13	11.78	11.65	1.11	0.13	9.00	5.00	0.312	24.0	0.0	
23.03.2023	64.66	37.59	27.07	11.41	11.04	3.30	11.17	11.04	1.17	0.13	9.00	5.00	0.304	24.0	0.0	
24.03.2023	65.06	38.86	26.20	12.31	11.94	3.05	12.07	11.94	1.08	0.13	9.00	5.00	0.316	24.0	0.0	
25.03.2023	66.98	40.63	26.35	13.28	12.90	2.90	13.04	12.86	1.39	0.18	9.00	5.00	0.343	24.0	0.0	
26.03.2023	66.80	41.86	24.94	13.96	13.55	2.98	13.72	13.46	1.91	0.26	9.00	5.00	0.345	24.0	0.0	
27.03.2023	66.28	42.00	24.28	14.29	13.88	2.91	14.05	13.76	2.09	0.29	9.00	5.00	0.342	24.0	0.0	
28.03.2023	65.40	39.93	25.47	11.49	11.11	3.36	11.27	11.11	1.43	0.16	9.00	5.00	0.287	24.0	0.0	
29.03.2023	67.13	39.53	27.60	11.74	11.37	3.20	11.50	11.37	1.14	0.13	9.00	5.00	0.317	24.0	0.0	
30.03.2023	65.14	37.72	27.42	10.45	10.09	3.51	10.21	10.09	1.18	0.12	9.00	5.00	0.280	24.0	0.0	
31.03.2023	64.60	37.52	27.08	10.87	10.51	3.37	10.63	10.51	1.14	0.12	9.00	5.00	0.288	24.0	0.0	
Средние:	69.71	40.49	29.22	---	---	0.16	---	---	-1.59	---	9.00	5.00	---	---	---	
Итого:	---	---	---	385.76	385.32	---	377.72	383.84	---	-6.12	---	---	11.116	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2023	653.39	828.06	631.43	817.00	-185.57	26.777	1475.0	1.0
31.03.2023	1039.15	1213.38	1009.15	1200.84	-191.69	37.893	2219.0	1.0
Итого:	385.76	385.32	377.72	383.84	-6.12	11.116	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации