

Отчет о суточных параметрах ГВС
(01.07.2023 0:00:00 - 31.07.2023 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	V1	M1	P1	Q1	Траб	NS	gNSCode
	°C	м3	т	кгс/см2	Гкал	ч		
01.07.2023	51.78	1.407	1.389	3.98	0.065	24.0		Ok
02.07.2023	52.85	1.818	1.794	4.12	0.086	24.0		Ok
03.07.2023	52.73	1.847	1.823	4.17	0.087	24.0		Ok
04.07.2023	51.83	1.419	1.401	4.17	0.066	24.0		Ok
05.07.2023	52.34	1.744	1.722	4.20	0.081	24.0		Ok
06.07.2023	52.27	1.481	1.462	3.97	0.069	24.0		Ok
07.07.2023	52.04	1.353	1.336	4.11	0.063	24.0		Ok
08.07.2023	52.19	1.427	1.409	4.27	0.066	24.0		Ok
09.07.2023	52.93	1.644	1.623	4.07	0.078	24.0		Ok
10.07.2023	52.05	1.528	1.509	3.89	0.071	24.0		Ok
11.07.2023	53.52	1.415	1.396	3.94	0.068	24.0		Ok
12.07.2023	55.22	1.606	1.583	4.10	0.079	24.0		Ok
13.07.2023	53.58	1.794	1.770	4.26	0.086	24.0		Ok
14.07.2023	51.96	1.369	1.352	4.22	0.063	24.0		Ok
15.07.2023	52.13	1.243	1.227	4.31	0.058	24.0		Ok
16.07.2023	53.94	1.819	1.794	4.21	0.088	24.0		Ok
17.07.2023	53.71	1.692	1.669	4.14	0.081	24.0		Ok
18.07.2023	53.27	2.010	1.983	4.21	0.096	24.0		Ok
19.07.2023	53.06	1.622	1.601	4.17	0.077	24.0		Ok
20.07.2023	52.12	1.478	1.459	4.08	0.069	24.0		Ok
21.07.2023	52.86	1.698	1.676	4.32	0.080	24.0		Ok
22.07.2023	52.34	1.672	1.651	4.19	0.078	24.0		Ok
23.07.2023	53.38	1.848	1.823	4.02	0.088	24.0		Ok
24.07.2023	40.50	2.048	2.031	4.34	0.072	24.0		Ok
25.07.2023	22.83	2.496	2.492	5.00	0.045	24.0		Ok
26.07.2023	22.27	1.284	1.282	4.96	0.022	24.0	*	IC V; HC I
27.07.2023	21.94	1.264	1.262	4.88	0.021	24.0		Ok
28.07.2023	21.40	1.368	1.366	4.95	0.022	24.0		Ok
29.07.2023	21.30	1.601	1.599	5.05	0.026	24.0		Ok
30.07.2023	21.44	1.122	1.121	4.99	0.018	24.0		Ok
31.07.2023	21.38	1.425	1.423	4.98	0.023	24.0		Ok
Средние:	45.39	---	---	4.33	---	---		
Итого:	---	49.542	49.030	---	1.994	744.0		

Дата	V1	M1	Q1	Траб
	м3	т	Гкал	ч
30.06.2023	961.893	948.054	47.853	14443.7
31.07.2023	1011.435	997.084	49.847	15187.7
Итого:	49.542	49.030	1.994	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.07.2023 0:00:00 - 31.07.2023 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: ВКТ-7 Заводской номер: 00115028
Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995
Обратка: ПРЭМ SN 333703
Схема измерений: Закрытая система отопления (Схема 3)

Датчик температуры: КТСП-Н SN 32048г
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Мг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.07.2023	29.52	28.13	1.39	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
02.07.2023	29.81	28.40	1.41	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
03.07.2023	29.96	28.53	1.43	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
04.07.2023	29.90	28.46	1.44	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
05.07.2023	29.98	28.61	1.37	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
06.07.2023	29.99	28.64	1.35	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
07.07.2023	30.00	28.67	1.33	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
08.07.2023	29.52	28.29	1.23	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
09.07.2023	30.44	29.08	1.36	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
10.07.2023	31.09	29.64	1.45	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
11.07.2023	31.16	29.79	1.37	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
12.07.2023	31.71	30.14	1.57	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
13.07.2023	30.20	28.80	1.40	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
14.07.2023	29.79	28.47	1.32	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
15.07.2023	29.71	28.42	1.29	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
16.07.2023	29.69	28.35	1.34	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
17.07.2023	30.03	28.65	1.38	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
18.07.2023	30.18	28.85	1.33	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
19.07.2023	30.03	28.68	1.35	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
20.07.2023	29.76	28.45	1.31	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
21.07.2023	29.65	28.36	1.29	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
22.07.2023	29.47	28.16	1.31	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
23.07.2023	29.26	27.99	1.27	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
24.07.2023	28.68	27.38	1.30	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
25.07.2023	24.66	23.99	0.67	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
26.07.2023	23.67	23.13	0.54	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
27.07.2023	23.56	23.05	0.51	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
28.07.2023	23.59	23.00	0.59	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
29.07.2023	23.34	22.75	0.59	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
30.07.2023	23.32	22.67	0.65	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
31.07.2023	23.38	22.69	0.69	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
Средние:	28.55	27.36	1.19	---	---	0.00	---	---	0.00	---	9.00	5.00	---	---	---	
Итого:	---	---	---	0.00	0.00	---	0.00	0.00	---	0.00	---	---	0.000	744.0	0.0	

Дата	V1	V2	M1	M2	Мг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
30.06.2023	1337.99	1502.60	1301.70	1489.84	-188.14	45.689	4403.0	1.0
31.07.2023	1337.99	1502.60	1301.70	1489.84	-188.14	45.689	5147.0	1.0
Итого:	0.00	0.00	0.00	0.00	0.00	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации