

Отчет о суточных параметрах ГВС  
(01.11.2023 0:00:00 - 30.11.2023 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: Карат-30X Заводской номер: 11432221  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.11.2023	55.42	1.757	1.732	4.18	0.087	24.0		Ok
02.11.2023	53.31	1.380	1.362	4.26	0.066	24.0		Ok
03.11.2023	53.17	1.331	1.313	4.25	0.063	24.0		Ok
04.11.2023	53.23	1.506	1.486	4.11	0.072	24.0		Ok
05.11.2023	52.57	1.630	1.609	3.98	0.077	24.0		Ok
06.11.2023	52.66	1.852	1.828	3.93	0.087	24.0		Ok
07.11.2023	52.91	1.875	1.851	4.00	0.089	24.0		Ok
08.11.2023	52.36	1.441	1.423	4.10	0.067	24.0		Ok
09.11.2023	54.01	1.518	1.497	3.97	0.073	24.0		Ok
10.11.2023	52.36	1.293	1.276	3.97	0.060	24.0		Ok
11.11.2023	53.99	1.772	1.748	3.37	0.086	24.0		Ok
12.11.2023	54.03	1.277	1.260	3.67	0.062	24.0		Ok
13.11.2023	52.50	1.495	1.476	3.92	0.070	24.0		Ok
14.11.2023	53.45	1.538	1.517	3.73	0.073	24.0		Ok
15.11.2023	52.35	1.310	1.293	4.00	0.061	24.0		Ok
16.11.2023	53.10	1.444	1.425	3.88	0.069	24.0		Ok
17.11.2023	52.97	1.506	1.486	4.01	0.071	24.0		Ok
18.11.2023	54.77	1.775	1.750	3.96	0.087	24.0		Ok
19.11.2023	53.60	1.675	1.653	3.60	0.080	24.0		Ok
20.11.2023	53.47	1.464	1.444	3.83	0.070	24.0		Ok
21.11.2023	52.44	1.195	1.180	4.14	0.056	24.0		Ok
22.11.2023	53.90	1.849	1.824	4.25	0.089	24.0		Ok
23.11.2023	53.50	1.529	1.509	4.22	0.073	24.0		Ok
24.11.2023	54.41	1.520	1.499	4.17	0.074	24.0		Ok
25.11.2023	54.93	1.824	1.798	4.15	0.090	24.0		Ok
26.11.2023	55.44	2.270	2.238	3.98	0.113	24.0		Ok
27.11.2023	55.30	2.093	2.063	4.11	0.104	24.0		Ok
28.11.2023	53.89	1.468	1.448	4.18	0.071	24.0		Ok
29.11.2023	53.90	1.718	1.695	4.23	0.083	24.0		Ok
30.11.2023	---	---	---	---	---	---		
Средние:	53.58	---	---	4.00	---	---		
Итого:	---	46.305	45.683	---	2.223	696.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.10.2023	1128.729	1112.903	55.248	17395.7
29.11.2023	1175.034	1158.586	57.471	18091.7
Итого:	46.305	45.683	2.223	696.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.11.2023 0:00:00 - 30.11.2023 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: ВКТ-7 Заводской номер: 00115028  
Точка измерения: ТВ1; Ресурс: ТС

Подача:  
Обратка:  
Схема измерений: Закрытая система отопления (Схема 3)

Счетчик воды:  
ПРЭМ SN 334995  
ПРЭМ SN 333703

Датчик температуры:  
КТСП-Н SN 32048г  
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.11.2023	70.55	41.49	29.06	13.23	12.97	1.98	12.99	12.96	0.23	0.03	9.00	5.00	0.376	24.0	0.0	
02.11.2023	67.40	39.81	27.59	12.79	12.50	2.29	12.55	12.50	0.40	0.05	9.00	5.00	0.349	24.0	0.0	
03.11.2023	68.86	42.23	26.63	14.30	14.01	2.05	14.06	13.87	1.36	0.19	9.00	5.00	0.375	24.0	0.0	
04.11.2023	68.15	38.91	29.24	12.59	12.31	2.25	12.35	12.31	0.32	0.04	9.00	5.00	0.360	24.0	0.0	
05.11.2023	69.89	39.73	30.16	13.02	12.75	2.10	12.78	12.75	0.24	0.03	9.00	5.00	0.385	24.0	0.0	
06.11.2023	66.42	37.25	29.17	11.88	11.60	2.39	11.64	11.60	0.34	0.04	9.00	5.00	0.339	24.0	0.0	
07.11.2023	66.77	39.48	27.29	13.43	13.13	2.26	13.19	13.13	0.46	0.06	9.00	5.00	0.361	24.0	0.0	
08.11.2023	66.62	39.78	26.84	13.02	12.73	2.25	12.78	12.73	0.39	0.05	9.00	5.00	0.343	24.0	0.0	
09.11.2023	66.40	39.70	26.70	12.85	12.56	2.28	12.61	12.56	0.40	0.05	9.00	5.00	0.339	24.0	0.0	
10.11.2023	65.79	39.36	26.43	12.48	12.19	2.35	12.24	12.19	0.41	0.05	9.00	5.00	0.325	24.0	0.0	
11.11.2023	65.90	39.43	26.47	12.42	12.12	2.44	12.18	12.12	0.49	0.06	9.00	5.00	0.323	24.0	0.0	
12.11.2023	65.63	38.51	27.12	11.90	11.61	2.47	11.66	11.61	0.43	0.05	9.00	5.00	0.318	24.0	0.0	
13.11.2023	65.98	38.77	27.21	12.33	12.04	2.38	12.09	12.04	0.41	0.05	9.00	5.00	0.331	24.0	0.0	
14.11.2023	66.45	40.35	26.10	13.40	13.10	2.26	13.16	13.09	0.53	0.07	9.00	5.00	0.345	24.0	0.0	
15.11.2023	65.77	39.28	26.49	12.37	12.08	2.37	12.13	12.08	0.41	0.05	9.00	5.00	0.321	24.0	0.0	
16.11.2023	66.24	39.24	27.00	12.46	12.17	2.35	12.22	12.17	0.41	0.05	9.00	5.00	0.332	24.0	0.0	
17.11.2023	68.80	39.86	28.94	12.53	12.25	2.26	12.29	12.25	0.33	0.04	9.00	5.00	0.353	24.0	0.0	
18.11.2023	77.24	42.94	34.30	13.37	13.15	1.66	13.02	13.05	-0.23	-0.03	9.00	5.00	0.446	24.0	0.0	
19.11.2023	80.08	43.74	36.34	13.17	12.98	1.45	12.76	12.91	-1.17	-0.15	9.00	5.00	0.462	24.0	0.0	
20.11.2023	79.69	44.10	35.59	13.46	13.26	1.50	13.08	13.12	-0.31	-0.04	9.00	5.00	0.465	24.0	0.0	
21.11.2023	77.57	42.49	35.08	12.81	12.61	1.57	12.51	12.60	-0.72	-0.09	9.00	5.00	0.438	24.0	0.0	
22.11.2023	76.06	41.87	34.19	12.75	12.53	1.74	12.51	12.53	-0.16	-0.02	9.00	5.00	0.429	24.0	0.0	
23.11.2023	79.96	42.95	37.01	12.80	12.60	1.57	12.43	12.60	-1.36	-0.17	9.00	5.00	0.460	24.0	0.0	
24.11.2023	88.67	45.53	43.14	12.84	12.72	0.94	12.36	12.59	-1.84	-0.23	9.00	5.00	0.533	24.0	0.0	
25.11.2023	85.45	44.43	41.02	12.75	12.61	1.10	12.33	12.50	-1.37	-0.17	9.00	5.00	0.507	24.0	0.0	
26.11.2023	75.24	41.82	33.42	12.61	12.39	1.76	12.29	12.31	-0.16	-0.02	9.00	5.00	0.412	24.0	0.0	
27.11.2023	67.21	37.97	29.24	11.78	11.50	2.41	11.54	11.50	0.35	0.04	9.00	5.00	0.340	24.0	0.0	
28.11.2023	69.04	38.83	30.21	12.21	11.94	2.24	11.97	11.94	0.25	0.03	9.00	5.00	0.360	24.0	0.0	
29.11.2023	69.86	40.51	29.35	13.29	13.01	2.13	13.05	13.01	0.31	0.04	9.00	5.00	0.386	24.0	0.0	
30.11.2023	72.89	41.65	31.24	13.47	13.22	1.87	13.18	13.16	0.15	0.02	9.00	5.00	0.412	24.0	0.0	
Средние:	71.35	40.73	30.62	---	---	2.02	---	---	0.04	---	9.00	5.00	---	---	---	
Итого:	---	---	---	384.31	376.64	---	375.95	375.78	---	0.17	---	---	11.525	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.10.2023	1432.37	1595.02	1394.32	1582.12	-187.80	48.545	7355.0	1.0
30.11.2023	1816.68	1971.66	1770.27	1957.90	-187.63	60.070	8075.0	1.0
Итого:	384.31	376.64	375.95	375.78	0.17	11.525	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации