

Отчет о суточных параметрах ГВС
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	V1	M1	P1	Q1	Траб	NS	gNSCode
	°C	м3	т	кгс/см2	Гкал	ч		
01.01.2024	55.04	2.071	2.042	4.06	0.102	24.0		Ok
02.01.2024	55.97	2.110	2.079	4.08	0.106	24.0		Ok
03.01.2024	56.21	2.087	2.056	3.80	0.105	24.0		Ok
04.01.2024	55.18	1.816	1.790	4.01	0.090	24.0		Ok
05.01.2024	55.43	1.662	1.638	3.83	0.083	24.0		Ok
06.01.2024	55.06	1.690	1.666	3.73	0.083	24.0		Ok
07.01.2024	55.32	1.814	1.788	3.87	0.090	24.0		Ok
08.01.2024	55.02	2.052	2.023	3.56	0.101	24.0		Ok
09.01.2024	54.13	1.465	1.445	3.80	0.071	24.0		Ok
10.01.2024	55.33	1.986	1.958	3.83	0.098	24.0		Ok
11.01.2024	54.21	1.334	1.316	3.84	0.065	24.0		Ok
12.01.2024	54.26	1.400	1.381	3.92	0.068	24.0		Ok
13.01.2024	54.86	1.586	1.564	3.66	0.078	24.0		Ok
14.01.2024	54.51	1.321	1.303	3.43	0.064	24.0		Ok
15.01.2024	54.56	1.716	1.692	3.72	0.084	24.0		Ok
16.01.2024	54.30	1.664	1.641	3.76	0.081	24.0		Ok
17.01.2024	53.02	1.431	1.412	3.86	0.068	24.0		Ok
18.01.2024	53.78	1.626	1.604	3.82	0.078	24.0		Ok
19.01.2024	53.40	1.497	1.477	3.77	0.071	24.0		Ok
20.01.2024	53.28	1.688	1.666	3.78	0.080	24.0		Ok
21.01.2024	53.70	2.177	2.148	3.51	0.105	24.0		Ok
22.01.2024	52.99	1.623	1.602	3.67	0.077	24.0		Ok
23.01.2024	53.18	1.600	1.579	3.83	0.076	24.0		Ok
24.01.2024	53.85	1.385	1.366	3.86	0.067	24.0		Ok
25.01.2024	53.37	1.320	1.302	3.89	0.063	24.0		Ok
26.01.2024	53.06	1.179	1.164	3.90	0.056	24.0		Ok
27.01.2024	54.01	1.301	1.283	3.76	0.063	24.0		Ok
28.01.2024	53.96	1.379	1.360	3.44	0.067	24.0		Ok
29.01.2024	54.28	1.653	1.630	3.72	0.080	24.0		Ok
30.01.2024	53.84	1.357	1.339	3.93	0.065	24.0		Ok
31.01.2024	53.40	1.494	1.474	3.89	0.071	24.0		Ok
Средние:	54.28	---	---	3.79	---	---		
Итого:	---	50.484	49.789	---	2.457	744.0		

Дата	V1	M1	Q1	Траб
	м3	т	Гкал	ч
31.12.2023	1224.999	1207.871	59.886	18859.7
31.01.2024	1275.483	1257.660	62.342	19603.7
Итого:	50.484	49.789	2.457	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: ВКТ-7 Заводской номер: 00115028
Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995
Обратка: ПРЭМ SN 333703
Схема измерений: Закрытая система отопления (Схема 3)

Датчик температуры:
КТСП-Н SN 32048г
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Мг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.01.2024	100.16	52.31	47.85	15.09	15.13	-0.26	14.38	14.89	-3.48	-0.51	9.00	5.00	0.688	24.0	0.0	
02.01.2024	104.90	52.50	52.40	14.55	14.65	-0.68	13.83	14.41	-4.11	-0.58	9.00	5.00	0.727	24.0	0.0	
03.01.2024	109.15	53.81	55.34	14.59	14.73	-0.95	13.87	14.49	-4.37	-0.62	9.00	5.00	0.770	24.0	0.0	
04.01.2024	107.02	54.18	52.84	14.96	15.09	-0.87	14.24	14.85	-4.19	-0.61	9.00	5.00	0.758	24.0	0.0	
05.01.2024	108.38	55.29	53.09	15.37	15.51	-0.91	14.65	15.27	-4.14	-0.62	9.00	5.00	0.781	24.0	0.0	
06.01.2024	107.98	52.97	55.01	14.42	14.55	-0.90	13.70	14.31	-4.36	-0.61	9.00	5.00	0.758	24.0	0.0	
07.01.2024	109.07	54.15	54.92	14.85	15.01	-1.07	14.13	14.77	-4.43	-0.64	9.00	5.00	0.779	24.0	0.0	
08.01.2024	108.54	53.37	55.17	14.60	14.75	-1.02	13.88	14.51	-4.44	-0.63	9.00	5.00	0.768	24.0	0.0	
09.01.2024	107.72	53.87	53.85	14.92	15.06	-0.93	14.20	14.82	-4.27	-0.62	9.00	5.00	0.765	24.0	0.0	
10.01.2024	106.85	52.80	54.05	14.45	14.59	-0.96	13.73	14.35	-4.42	-0.62	9.00	5.00	0.746	24.0	0.0	
11.01.2024	106.81	52.51	54.30	14.42	14.55	-0.90	13.70	14.31	-4.36	-0.61	9.00	5.00	0.746	24.0	0.0	
12.01.2024	106.36	53.15	53.21	14.68	14.81	-0.88	13.96	14.57	-4.28	-0.61	9.00	5.00	0.747	24.0	0.0	
13.01.2024	105.61	51.23	54.38	13.99	14.12	-0.92	13.34	13.88	-3.97	-0.54	9.00	5.00	0.728	24.0	0.0	
14.01.2024	106.20	52.49	53.71	14.62	14.75	-0.89	13.90	14.51	-4.29	-0.61	9.00	5.00	0.749	24.0	0.0	
15.01.2024	98.74	50.45	48.29	14.47	14.53	-0.41	13.87	14.29	-2.98	-0.42	9.00	5.00	0.674	24.0	0.0	
16.01.2024	89.16	45.89	43.27	13.68	13.57	0.81	13.20	13.34	-1.06	-0.14	9.00	5.00	0.571	24.0	0.0	
17.01.2024	82.02	42.88	39.14	12.85	12.58	2.12	12.45	12.48	-0.24	-0.03	9.00	5.00	0.490	24.0	0.0	
18.01.2024	84.09	45.00	39.09	14.27	13.97	2.12	13.79	13.75	0.29	0.04	9.00	5.00	0.539	24.0	0.0	
19.01.2024	85.23	45.12	40.11	14.15	13.86	2.07	13.67	13.62	0.37	0.05	9.00	5.00	0.551	24.0	0.0	
20.01.2024	78.94	40.66	38.28	10.25	9.96	2.87	9.90	9.85	0.51	0.05	9.00	5.00	0.382	24.0	0.0	
21.01.2024	74.97	39.63	35.34	13.50	13.15	2.63	13.21	13.13	0.61	0.08	9.00	5.00	0.468	24.0	0.0	
22.01.2024	86.14	45.33	40.81	14.52	14.23	2.02	14.04	13.99	0.36	0.05	9.00	5.00	0.574	24.0	0.0	
23.01.2024	89.24	47.35	41.89	14.77	14.53	1.64	14.29	14.29	0.00	0.00	9.00	5.00	0.601	24.0	0.0	
24.01.2024	89.75	49.41	40.34	15.75	15.51	1.54	15.27	15.27	0.00	0.00	9.00	5.00	0.620	24.0	0.0	
25.01.2024	88.90	49.26	39.64	15.56	15.30	1.69	15.08	15.06	0.13	0.02	9.00	5.00	0.600	24.0	0.0	
26.01.2024	89.97	50.44	39.53	16.12	15.88	1.50	15.63	15.64	-0.06	-0.01	9.00	5.00	0.621	24.0	0.0	
27.01.2024	89.10	49.79	39.31	15.66	15.42	1.54	15.18	15.18	0.00	0.00	9.00	5.00	0.599	24.0	0.0	
28.01.2024	86.49	48.19	38.30	15.01	14.76	1.68	14.53	14.52	0.07	0.01	9.00	5.00	0.558	24.0	0.0	
29.01.2024	83.35	46.69	36.66	14.76	14.48	1.92	14.28	14.24	0.28	0.04	9.00	5.00	0.527	24.0	0.0	
30.01.2024	80.94	46.60	34.34	15.26	14.95	2.05	14.78	14.71	0.47	0.07	9.00	5.00	0.506	24.0	0.0	
31.01.2024	75.30	44.29	31.01	14.70	14.35	2.41	14.34	14.16	1.26	0.18	9.00	5.00	0.447	24.0	0.0	
Средние:	95.07	49.41	45.66	---	---	0.58	---	---	-1.91	---	9.00	5.00	---	---	---	
Итого:	---	---	---	450.79	448.33	---	433.02	441.46	---	-8.44	---	---	19.838	744.0	0.0	

Дата	V1	V2	M1	M2	Мг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.12.2023	2235.88	2388.52	2174.72	2369.95	-195.23	77.595	8819.0	1.0
31.01.2024	2686.67	2836.85	2607.74	2811.41	-203.67	97.433	9563.0	1.0
Итого:	450.79	448.33	433.02	441.46	-8.44	19.838	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации