

Отчет о суточных параметрах ГВС  
(01.02.2024 0:00:00 - 29.02.2024 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: Карат-30X Заводской номер: 11432221  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	V1	M1	P1	Q1	Траб	NS	gNSCode
	°C	м3	т	кгс/см2	Гкал	ч		
01.02.2024	54.45	1.870	1.844	3.79	0.091	24.0		Ok
02.02.2024	53.18	1.393	1.375	3.87	0.066	24.0		Ok
03.02.2024	54.43	1.775	1.750	3.81	0.086	24.0		Ok
04.02.2024	55.20	1.551	1.529	3.53	0.077	24.0		Ok
05.02.2024	53.59	1.734	1.711	3.66	0.083	24.0		Ok
06.02.2024	54.65	1.662	1.639	3.91	0.081	24.0		Ok
07.02.2024	52.78	1.381	1.363	3.86	0.065	24.0		Ok
08.02.2024	54.04	1.535	1.514	3.93	0.074	24.0		Ok
09.02.2024	54.44	1.931	1.904	3.85	0.094	24.0		Ok
10.02.2024	55.48	1.682	1.658	3.73	0.084	24.0		Ok
11.02.2024	55.01	1.663	1.639	3.44	0.082	24.0		Ok
12.02.2024	54.01	1.614	1.592	3.74	0.078	24.0		Ok
13.02.2024	54.17	1.503	1.482	3.98	0.073	24.0		Ok
14.02.2024	54.55	1.578	1.556	3.88	0.077	24.0		Ok
15.02.2024	54.42	1.492	1.471	3.82	0.073	24.0		Ok
16.02.2024	54.99	1.854	1.828	3.77	0.091	24.0		Ok
17.02.2024	54.56	1.465	1.445	3.68	0.072	24.0		Ok
18.02.2024	55.43	2.018	1.989	3.44	0.100	24.0		Ok
19.02.2024	53.58	1.434	1.415	3.72	0.069	24.0		Ok
20.02.2024	53.34	1.328	1.310	3.70	0.063	24.0		Ok
21.02.2024	53.52	1.604	1.583	3.81	0.077	24.0		Ok
22.02.2024	53.08	1.358	1.340	3.92	0.064	24.0		Ok
23.02.2024	53.00	1.256	1.240	3.77	0.059	24.0		Ok
24.02.2024	54.42	1.630	1.607	3.91	0.079	24.0		Ok
25.02.2024	54.60	1.308	1.290	3.52	0.064	24.0		Ok
26.02.2024	53.62	1.773	1.749	3.71	0.085	24.0		Ok
27.02.2024	53.41	1.508	1.488	3.84	0.072	24.0		Ok
28.02.2024	54.25	1.850	1.825	3.90	0.090	24.0		Ok
29.02.2024	53.85	1.751	1.727	3.82	0.084	24.0		Ok
Средние:	54.14	---	---	3.77	---	---		
Итого:	---	46.501	45.864	---	2.255	696.0		

Дата	V1	M1	Q1	Траб
	м3	т	Гкал	ч
31.01.2024	1275.483	1257.660	62.342	19603.7
29.02.2024	1321.984	1303.524	64.597	20299.7
Итого:	46.501	45.864	2.255	696.0

Представитель абонента

\_\_\_\_\_

Представитель энергоснабжающей организации

\_\_\_\_\_

Отчет о суточных параметрах  
(01.02.2024 0:00:00 - 29.02.2024 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: ВКТ-7 Заводской номер: 00115028  
Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995  
Обратка: ПРЭМ SN 333703  
Схема измерений: Закрытая система отопления (Схема 3)

Датчик температуры:  
КТСП-Н SN 32048г  
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Мг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.02.2024	75.37	44.13	31.24	14.90	14.56	2.31	14.50	14.33	1.18	0.17	9.00	5.00	0.455	24.0	0.0	
02.02.2024	77.02	44.09	32.93	14.47	14.13	2.38	14.00	13.89	0.79	0.11	9.00	5.00	0.461	24.0	0.0	
03.02.2024	80.11	44.77	35.34	14.26	13.96	2.13	13.78	13.72	0.44	0.06	9.00	5.00	0.490	24.0	0.0	
04.02.2024	82.77	47.23	35.54	15.28	14.99	1.92	14.80	14.75	0.34	0.05	9.00	5.00	0.529	24.0	0.0	
05.02.2024	79.65	44.70	34.95	14.28	13.97	2.19	13.80	13.74	0.44	0.06	9.00	5.00	0.484	24.0	0.0	
06.02.2024	77.34	45.27	32.07	15.25	14.92	2.19	14.80	14.68	0.81	0.12	9.00	5.00	0.474	24.0	0.0	
07.02.2024	74.89	43.68	31.21	14.63	14.28	2.42	14.27	14.04	1.62	0.23	9.00	5.00	0.444	24.0	0.0	
08.02.2024	80.28	45.90	34.38	15.03	14.71	2.15	14.55	14.47	0.55	0.08	9.00	5.00	0.502	24.0	0.0	
09.02.2024	89.30	49.05	40.25	15.25	15.03	1.45	14.77	14.79	-0.14	-0.02	9.00	5.00	0.596	24.0	0.0	
10.02.2024	97.73	51.53	46.20	15.07	14.93	0.93	14.51	14.69	-1.23	-0.18	9.00	5.00	0.672	24.0	0.0	
11.02.2024	98.51	52.62	45.89	15.57	15.42	0.97	14.88	15.18	-2.00	-0.30	9.00	5.00	0.686	24.0	0.0	
12.02.2024	97.32	52.20	45.12	15.71	15.57	0.90	15.03	15.33	-1.98	-0.30	9.00	5.00	0.681	24.0	0.0	
13.02.2024	95.92	52.96	42.96	16.32	16.15	1.05	15.65	15.91	-1.65	-0.26	9.00	5.00	0.676	24.0	0.0	
14.02.2024	103.73	54.09	49.64	15.64	15.55	0.58	14.94	15.31	-2.45	-0.37	9.00	5.00	0.742	24.0	0.0	
15.02.2024	110.14	55.67	54.47	15.35	15.35	0.00	14.63	15.11	-3.23	-0.48	9.00	5.00	0.800	24.0	0.0	
16.02.2024	109.53	54.35	55.18	14.99	14.98	0.07	14.27	14.74	-3.24	-0.47	9.00	5.00	0.791	24.0	0.0	
17.02.2024	106.37	54.73	51.64	15.55	15.49	0.39	14.83	15.25	-2.79	-0.42	9.00	5.00	0.770	24.0	0.0	
18.02.2024	98.02	52.07	45.95	15.55	15.42	0.84	14.93	15.18	-1.66	-0.25	9.00	5.00	0.689	24.0	0.0	
19.02.2024	87.49	47.96	39.53	14.95	14.72	1.55	14.47	14.48	-0.07	-0.01	9.00	5.00	0.572	24.0	0.0	
20.02.2024	86.79	47.01	39.78	14.65	14.42	1.58	14.17	14.18	-0.07	-0.01	9.00	5.00	0.564	24.0	0.0	
21.02.2024	89.28	47.94	41.34	14.72	14.52	1.37	14.24	14.28	-0.28	-0.04	9.00	5.00	0.587	24.0	0.0	
22.02.2024	91.70	48.80	42.90	14.71	14.53	1.23	14.23	14.29	-0.42	-0.06	9.00	5.00	0.610	24.0	0.0	
23.02.2024	91.51	48.21	43.30	14.46	14.27	1.32	13.98	14.03	-0.36	-0.05	9.00	5.00	0.607	24.0	0.0	
24.02.2024	91.50	49.24	42.26	15.08	14.89	1.27	14.60	14.65	-0.34	-0.05	9.00	5.00	0.618	24.0	0.0	
25.02.2024	87.15	49.10	38.05	15.54	15.30	1.56	15.06	15.06	0.00	0.00	9.00	5.00	0.574	24.0	0.0	
26.02.2024	82.07	46.38	35.69	15.08	14.80	1.87	14.60	14.56	0.27	0.04	9.00	5.00	0.523	24.0	0.0	
27.02.2024	81.10	46.18	34.92	14.90	14.63	1.83	14.43	14.39	0.28	0.04	9.00	5.00	0.507	24.0	0.0	
28.02.2024	78.21	44.33	33.88	14.36	14.05	2.18	13.88	13.81	0.51	0.07	9.00	5.00	0.471	24.0	0.0	
29.02.2024	76.80	43.85	32.95	14.28	13.97	2.19	13.87	13.78	0.65	0.09	9.00	5.00	0.460	24.0	0.0	
Средние:	88.88	48.55	40.33	---	---	1.48	---	---	-0.48	---	9.00	5.00	---	---	---	
Итого:	---	---	---	435.83	429.51	---	420.47	422.62	---	-2.15	---	---	17.035	696.0	0.0	

Дата	V1	V2	M1	M2	Мг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.01.2024	2686.67	2836.85	2607.74	2811.41	-203.67	97.433	9563.0	1.0
29.02.2024	3122.50	3266.36	3028.21	3234.03	-205.82	114.468	10259.0	1.0
Итого:	435.83	429.51	420.47	422.62	-2.15	17.035	696.0	0.0

Представитель абонента

Представитель энергоснабжающей организации