

Отчет о суточных параметрах ГВС
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	V1	M1	P1	Q1	Траб	NS	gNSCode
	°C	м3	т	кгс/см2	Гкал	ч		
01.03.2024	53.82	1.493	1.473	3.63	0.072	24.0		Ok
02.03.2024	53.88	1.663	1.640	3.54	0.080	24.0		Ok
03.03.2024	54.35	1.723	1.699	3.29	0.084	24.0		Ok
04.03.2024	53.67	1.788	1.764	3.51	0.086	24.0		Ok
05.03.2024	53.80	1.589	1.568	3.68	0.076	24.0	*	IC V; HC I
06.03.2024	53.59	1.632	1.610	3.77	0.078	24.0		Ok
07.03.2024	54.21	1.444	1.424	3.66	0.070	24.0		Ok
08.03.2024	55.01	1.760	1.735	3.63	0.087	24.0		Ok
09.03.2024	53.88	1.430	1.411	3.71	0.069	24.0		Ok
10.03.2024	54.63	1.455	1.435	3.56	0.071	24.0		Ok
11.03.2024	54.81	1.868	1.842	3.55	0.092	24.0		Ok
12.03.2024	54.41	1.583	1.561	3.66	0.077	24.0		Ok
13.03.2024	54.20	1.412	1.393	3.67	0.068	24.0		Ok
14.03.2024	53.75	1.555	1.534	3.82	0.075	24.0		Ok
15.03.2024	53.65	1.653	1.631	4.04	0.079	24.0		Ok
16.03.2024	53.65	1.585	1.564	3.86	0.076	24.0		Ok
17.03.2024	54.60	1.699	1.675	3.49	0.083	24.0		Ok
18.03.2024	54.02	1.622	1.600	3.77	0.078	24.0		Ok
19.03.2024	53.24	1.586	1.565	3.81	0.075	24.0		Ok
20.03.2024	52.85	1.508	1.488	3.91	0.071	24.0		Ok
21.03.2024	52.05	1.398	1.380	3.90	0.065	24.0		Ok
22.03.2024	52.21	1.408	1.390	3.93	0.066	24.0		Ok
23.03.2024	52.86	1.434	1.415	3.97	0.068	24.0		Ok
24.03.2024	54.07	1.858	1.833	3.56	0.090	24.0		Ok
25.03.2024	51.66	1.357	1.340	3.86	0.062	24.0		Ok
26.03.2024	52.12	1.359	1.342	3.93	0.063	24.0		Ok
27.03.2024	52.13	1.596	1.576	3.98	0.074	24.0		Ok
28.03.2024	54.44	1.758	1.734	3.81	0.086	24.0		Ok
29.03.2024	54.02	1.658	1.635	3.86	0.080	24.0		Ok
30.03.2024	52.99	1.457	1.438	3.89	0.069	24.0		Ok
31.03.2024	53.12	1.484	1.464	3.62	0.070	24.0		Ok
Средние:	53.60	---	---	3.74	---	---		
Итого:	---	48.815	48.159	---	2.342	744.0		

Дата	V1	M1	Q1	Траб
	м3	т	Гкал	ч
29.02.2024	1321.984	1303.524	64.597	20299.7
31.03.2024	1370.799	1351.683	66.939	21043.7
Итого:	48.815	48.159	2.342	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: ВКТ-7 Заводской номер: 00115028
Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995
Обратка: ПРЭМ SN 333703
Схема измерений: Закрытая система отопления (Схема 3)

Датчик температуры:
КТСП-Н SN 32048г
КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2024	76.12	44.07	32.05	14.67	14.36	2.14	14.22	14.12	0.71	0.10	9.00	5.00	0.458	24.0	0.0	
02.03.2024	75.18	44.35	30.83	14.93	14.61	2.17	14.52	14.37	1.04	0.15	9.00	5.00	0.449	24.0	0.0	
03.03.2024	74.13	44.01	30.12	14.72	14.40	2.20	14.36	14.21	1.05	0.15	9.00	5.00	0.434	24.0	0.0	
04.03.2024	78.33	47.44	30.89	16.55	16.22	2.01	16.13	16.00	0.81	0.13	9.00	5.00	0.497	24.0	0.0	
05.03.2024	73.36	43.94	29.42	14.51	14.20	2.16	14.23	14.06	1.20	0.17	9.00	5.00	0.420	24.0	0.0	
06.03.2024	83.17	46.58	36.59	14.78	14.54	1.64	14.32	14.32	0.00	0.00	9.00	5.00	0.522	24.0	0.0	
07.03.2024	86.57	49.36	37.21	15.73	15.51	1.41	15.25	15.27	-0.13	-0.02	9.00	5.00	0.571	24.0	0.0	
08.03.2024	79.63	46.84	32.79	15.48	15.19	1.89	15.00	14.95	0.33	0.05	9.00	5.00	0.495	24.0	0.0	
09.03.2024	76.06	44.66	31.40	14.63	14.35	1.93	14.20	14.14	0.42	0.06	9.00	5.00	0.447	24.0	0.0	
10.03.2024	85.69	47.74	37.95	14.96	14.75	1.41	14.50	14.52	-0.14	-0.02	9.00	5.00	0.553	24.0	0.0	
11.03.2024	91.81	50.62	41.19	15.42	15.24	1.17	14.90	15.00	-0.67	-0.10	9.00	5.00	0.616	24.0	0.0	
12.03.2024	88.82	50.04	38.78	15.63	15.43	1.29	15.15	15.19	-0.26	-0.04	9.00	5.00	0.591	24.0	0.0	
13.03.2024	84.02	47.58	36.44	14.94	14.72	1.48	14.46	14.48	-0.14	-0.02	9.00	5.00	0.528	24.0	0.0	
14.03.2024	76.79	46.17	30.62	15.74	15.45	1.86	15.30	15.21	0.59	0.09	9.00	5.00	0.470	24.0	0.0	
15.03.2024	73.60	44.39	29.21	15.29	14.99	1.98	14.89	14.75	0.94	0.14	9.00	5.00	0.437	24.0	0.0	
16.03.2024	73.54	45.00	28.54	15.74	15.43	1.99	15.26	15.19	0.46	0.07	9.00	5.00	0.436	24.0	0.0	
17.03.2024	73.70	45.45	28.25	16.00	15.69	1.96	15.54	15.45	0.58	0.09	9.00	5.00	0.440	24.0	0.0	
18.03.2024	73.25	45.78	27.47	16.33	16.02	1.92	15.89	15.78	0.69	0.11	9.00	5.00	0.437	24.0	0.0	
19.03.2024	72.64	44.59	28.05	15.57	15.28	1.88	15.19	15.10	0.59	0.09	9.00	5.00	0.426	24.0	0.0	
20.03.2024	70.71	43.65	27.06	15.42	15.11	2.03	15.10	14.92	1.20	0.18	9.00	5.00	0.411	24.0	0.0	
21.03.2024	67.81	41.78	26.03	14.74	14.44	2.06	14.50	14.33	1.18	0.17	9.00	5.00	0.378	24.0	0.0	
22.03.2024	71.34	45.14	26.20	16.77	16.44	1.99	16.40	16.20	1.23	0.20	9.00	5.00	0.431	24.0	0.0	
23.03.2024	72.33	45.73	26.60	16.90	16.59	1.85	16.49	16.35	0.85	0.14	9.00	5.00	0.440	24.0	0.0	
24.03.2024	68.48	42.48	26.00	14.46	14.16	2.10	14.18	14.07	0.78	0.11	9.00	5.00	0.369	24.0	0.0	
25.03.2024	67.70	41.54	26.16	14.57	14.27	2.08	14.33	14.19	0.98	0.14	9.00	5.00	0.377	24.0	0.0	
26.03.2024	68.14	42.76	25.38	15.37	15.07	1.97	15.13	14.88	1.67	0.25	9.00	5.00	0.385	24.0	0.0	
27.03.2024	67.55	42.05	25.50	14.86	14.56	2.04	14.62	14.40	1.52	0.22	9.00	5.00	0.374	24.0	0.0	
28.03.2024	70.21	41.70	28.51	14.07	13.80	1.94	13.83	13.76	0.51	0.07	9.00	5.00	0.396	24.0	0.0	
29.03.2024	72.79	42.93	29.86	14.64	14.38	1.79	14.36	14.21	1.05	0.15	9.00	5.00	0.428	24.0	0.0	
30.03.2024	68.12	41.31	26.81	14.12	13.83	2.08	13.88	13.78	0.72	0.10	9.00	5.00	0.373	24.0	0.0	
31.03.2024	67.54	41.12	26.42	14.17	13.89	2.00	13.93	13.83	0.72	0.10	9.00	5.00	0.370	24.0	0.0	
Средние:	75.13	44.86	30.27	---	---	1.88	---	---	0.66	---	9.00	5.00	---	---	---	
Итого:	---	---	---	471.71	462.92	---	460.06	457.03	---	3.03	---	---	13.959	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
29.02.2024	3122.50	3266.36	3028.21	3234.03	-205.82	114.468	10259.0	1.0
31.03.2024	3594.21	3729.28	3488.27	3691.06	-202.79	128.427	11003.0	1.0
Итого:	471.71	462.92	460.06	457.03	3.03	13.959	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации