

Отчет о суточных параметрах
(01.08.2022 0:00:00 - 31.08.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 19 (4 МКД "Заречная УК")
Прибор: ИМ2300 А-Е Заводской номер: СА537
Точка измерения: Узел 1; Ресурс: ТС

Подача:
Обратка:
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:
ПРИМ SN 10174
ПРИМ SN 10246

Датчик температуры:
КТПТР-06 SN 4276
КТПТР-06 SN 4276a

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.08.2022	18.48	17.93	0.54	0.00	0.00	---	0.000	0.0	24.0
02.08.2022	18.59	18.02	0.57	0.00	0.00	---	0.000	0.0	24.0
03.08.2022	18.51	17.99	0.52	0.00	0.00	---	0.000	0.0	24.0
04.08.2022	18.45	17.95	0.50	0.00	0.00	---	0.000	0.0	24.0
05.08.2022	18.49	17.96	0.52	0.00	0.00	---	0.000	0.0	24.0
06.08.2022	18.64	18.06	0.58	0.00	0.00	---	0.000	0.0	24.0
07.08.2022	18.84	18.22	0.62	0.00	0.00	---	0.000	0.0	24.0
08.08.2022	18.91	18.31	0.60	0.00	0.00	---	0.000	0.0	24.0
09.08.2022	19.07	18.45	0.62	0.00	0.00	---	0.000	0.0	24.0
10.08.2022	19.23	18.59	0.64	0.00	0.00	---	0.000	0.0	24.0
11.08.2022	19.39	18.74	0.64	0.00	0.00	---	0.000	0.0	24.0
12.08.2022	19.22	18.69	0.54	0.00	0.00	0.00	0.000	0.0	24.0
13.08.2022	18.77	18.30	0.48	0.00	0.00	0.00	0.000	0.0	24.0
14.08.2022	18.77	18.30	0.47	0.00	0.00	---	0.000	0.0	24.0
15.08.2022	18.33	17.90	0.42	0.00	0.00	---	0.000	0.0	24.0
16.08.2022	18.09	17.70	0.39	0.00	0.00	---	0.000	0.0	24.0
17.08.2022	17.89	17.58	0.31	0.00	0.00	0.00	0.000	0.0	24.0
18.08.2022	17.79	17.44	0.36	0.00	0.00	---	0.000	0.0	24.0
19.08.2022	17.65	17.31	0.34	0.00	0.00	---	0.000	0.0	24.0
20.08.2022	17.29	16.95	0.34	0.00	0.00	---	0.000	0.0	24.0
21.08.2022	17.39	17.04	0.34	0.00	0.00	---	0.000	0.0	24.0
22.08.2022	17.68	17.27	0.41	0.00	0.00	---	0.000	0.0	24.0
23.08.2022	17.92	17.46	0.45	0.22	0.22	-0.01	0.000	7.2	24.0
24.08.2022	17.94	17.50	0.45	0.72	0.72	-0.01	0.000	24.0	24.0
25.08.2022	18.12	17.64	0.48	0.72	0.72	-0.01	0.000	24.0	24.0
26.08.2022	18.38	17.84	0.54	0.72	0.72	-0.01	0.000	24.0	24.0
27.08.2022	18.61	18.04	0.57	0.72	0.72	-0.01	0.000	24.0	24.0
28.08.2022	18.65	18.12	0.53	0.72	0.72	-0.01	0.000	23.9	24.0
29.08.2022	18.42	17.95	0.47	0.70	0.70	-0.01	0.000	23.5	24.0
30.08.2022	18.60	18.08	0.52	0.69	0.69	-0.01	0.000	23.0	24.0
31.08.2022	18.74	18.21	0.53	0.62	0.62	-0.01	0.000	20.8	24.0
Средние:	18.41	17.92	0.49	---	---	0.00	---	---	---
Итого:	---	---	---	5.83	5.83	---	0.003	194.4	744.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.07.2022	0.00	0.00	0.000	0.0	755.1
31.08.2022	5.83	5.83	0.003	194.4	1499.1
Итого:	5.83	5.83	0.003	194.4	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.09.2022 0:00:00 - 08.10.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 19 (4 МКД "Заречная УК")
Прибор: ИМ2300 А-Е Заводской номер: СА537
Точка измерения: Узел 1; Ресурс: ТС

Подача:
Обратка:
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:
ПРИМ SN 10174
ПРИМ SN 10246

Датчик температуры:
КТПТР-06 SN 4276
КТПТР-06 SN 4276a

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.09.2022	18.89	18.33	0.56	0.50	0.50	-0.01	0.000	16.6	24.0
02.09.2022	19.78	20.77	-0.98	0.72	0.72	0.02	0.000	8.2	24.0
03.09.2022	21.67	24.08	-2.40	0.72	0.72	0.06	0.000	0.0	24.0
04.09.2022	21.69	23.53	-1.84	0.72	0.72	0.05	0.000	0.0	24.0
05.09.2022	21.38	22.96	-1.57	0.72	0.72	0.04	0.000	0.0	24.0
06.09.2022	20.55	21.65	-1.10	0.72	0.72	0.03	0.000	0.9	24.0
07.09.2022	18.27	17.97	0.30	0.72	0.72	-0.01	0.000	24.0	24.0
08.09.2022	17.14	16.79	0.35	0.72	0.72	-0.01	0.000	24.0	24.0
09.09.2022	16.65	16.37	0.29	0.72	0.72	-0.01	0.000	23.9	24.0
10.09.2022	16.15	15.86	0.29	0.72	0.72	-0.01	0.000	24.0	24.0
11.09.2022	15.37	15.06	0.31	0.72	0.72	-0.01	0.000	24.0	24.0
12.09.2022	15.30	15.10	0.20	0.71	0.71	0.00	0.000	23.5	24.0
13.09.2022	15.21	15.05	0.16	0.59	0.59	0.00	0.000	19.7	24.0
14.09.2022	15.12	14.98	0.15	0.50	0.50	0.00	0.000	16.8	24.0
15.09.2022	15.15	15.03	0.11	0.71	0.71	0.00	0.000	23.5	24.0
16.09.2022	15.40	15.32	0.08	0.72	0.72	0.00	0.000	24.0	24.0
17.09.2022	15.54	15.43	0.10	0.72	0.72	0.00	0.000	23.9	24.0
18.09.2022	15.59	15.47	0.12	0.71	0.71	0.00	0.000	23.7	24.0
19.09.2022	15.80	15.71	0.09	0.70	0.70	0.00	0.000	23.5	24.0
20.09.2022	15.91	15.81	0.09	0.67	0.67	0.00	0.000	22.5	24.0
21.09.2022	16.22	16.14	0.08	0.64	0.64	0.00	0.000	21.2	24.0
22.09.2022	16.10	15.97	0.14	0.72	0.72	0.00	0.000	24.0	24.0
23.09.2022	16.06	15.93	0.13	0.72	0.72	0.00	0.000	24.0	24.0
24.09.2022	16.17	16.06	0.11	0.72	0.72	0.00	0.000	24.0	24.0
25.09.2022	16.30	16.19	0.12	0.72	0.72	0.00	0.000	24.0	24.0
26.09.2022	15.94	15.74	0.20	0.72	0.72	0.00	0.000	24.0	24.0
27.09.2022	14.62	14.23	0.39	0.69	0.69	-0.01	0.000	23.1	24.0
28.09.2022	13.08	12.70	0.38	0.45	0.45	0.00	0.000	11.9	24.0
29.09.2022	11.58	11.19	0.39	0.15	0.15	-0.01	0.000	4.9	24.0
30.09.2022	47.27	33.30	13.97	16.77	16.95	-1.06	0.361	16.0	24.0
01.10.2022	68.41	47.52	20.89	25.15	25.41	-1.04	0.525	24.0	24.0
02.10.2022	67.88	48.01	19.87	25.20	25.45	-0.99	0.500	24.0	24.0
03.10.2022	67.30	49.35	17.95	27.25	27.49	-0.90	0.489	24.0	24.0
04.10.2022	66.65	49.57	17.09	27.73	27.97	-0.85	0.473	24.0	24.0
05.10.2022	66.74	48.48	18.26	24.56	24.78	-0.90	0.443	24.0	24.0
06.10.2022	66.83	46.33	20.50	20.41	20.62	-1.01	0.418	24.0	24.0
07.10.2022	67.01	46.25	20.76	20.15	20.35	-1.02	0.417	24.0	24.0
08.10.2022	67.97	47.88	20.09	21.56	21.78	-1.01	0.433	24.0	24.0
Средние:	28.12	23.74	4.38	---	---	-0.23	---	---	---
Итого:	---	---	---	228.01	230.04	---	4.063	735.7	912.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.08.2022	5.83	5.83	0.003	194.4	1499.1
08.10.2022	233.83	235.86	4.066	930.1	2411.1
Итого:	228.01	230.04	4.063	735.7	912.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.10.2022 0:00:00 - 31.10.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 19 (4 МКД "Заречная УК")
Прибор: ИМ2300 А-Е Заводской номер: СА537
Точка измерения: Узел 1; Ресурс: ТС

Подача: Счетчик воды:
Обратка: ПРИМ SN 10174
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Датчик температуры:
КТПТР-06 SN 4276
КТПТР-06 SN 4276а

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.10.2022	68.41	47.52	20.89	25.15	25.41	-1.04	0.525	24.0	24.0
02.10.2022	67.88	48.01	19.87	25.20	25.45	-0.99	0.500	24.0	24.0
03.10.2022	67.30	49.35	17.95	27.25	27.49	-0.90	0.489	24.0	24.0
04.10.2022	66.65	49.57	17.09	27.73	27.97	-0.85	0.473	24.0	24.0
05.10.2022	66.74	48.48	18.26	24.56	24.78	-0.90	0.443	24.0	24.0
06.10.2022	66.83	46.33	20.50	20.41	20.62	-1.01	0.418	24.0	24.0
07.10.2022	67.01	46.25	20.76	20.15	20.35	-1.02	0.417	24.0	24.0
08.10.2022	67.97	47.88	20.09	21.56	21.78	-1.01	0.433	24.0	24.0
09.10.2022	68.94	47.17	21.77	20.28	20.50	-1.09	0.441	24.0	24.0
10.10.2022	69.09	48.12	20.97	21.07	21.29	-1.06	0.441	24.0	24.0
11.10.2022	68.48	47.85	20.63	20.73	20.94	-1.03	0.427	24.0	24.0
12.10.2022	69.26	46.82	22.44	18.94	19.16	-1.12	0.425	24.0	24.0
13.10.2022	68.23	45.97	22.26	18.43	18.64	-1.10	0.410	24.0	24.0
14.10.2022	68.66	47.76	20.90	20.53	20.74	-1.05	0.428	24.0	24.0
15.10.2022	68.35	46.88	21.47	19.15	19.35	-1.07	0.410	24.0	24.0
16.10.2022	68.84	46.32	22.52	18.73	18.94	-1.12	0.421	24.0	24.0
17.10.2022	67.97	44.89	23.08	17.45	17.64	-1.13	0.402	24.0	24.0
18.10.2022	68.12	45.21	22.91	18.03	18.23	-1.12	0.412	24.0	24.0
19.10.2022	68.12	45.10	23.03	17.77	17.98	-1.13	0.408	24.0	24.0
20.10.2022	67.81	44.27	23.53	16.83	17.02	-1.14	0.395	24.0	24.0
21.10.2022	67.16	42.31	24.85	15.49	15.67	-1.19	0.384	24.0	24.0
22.10.2022	67.83	43.41	24.43	16.84	17.04	-1.18	0.411	24.0	24.0
23.10.2022	65.26	42.43	22.83	17.48	17.67	-1.08	0.398	24.0	24.0
24.10.2022	67.71	44.56	23.15	19.12	19.34	-1.13	0.442	24.0	24.0
25.10.2022	68.11	45.14	22.97	19.27	19.49	-1.12	0.441	24.0	24.0
26.10.2022	68.70	45.37	23.32	19.66	19.89	-1.14	0.454	24.0	24.0
27.10.2022	69.27	46.73	22.54	20.97	21.21	-1.12	0.472	24.0	24.0
28.10.2022	68.60	44.24	24.36	18.48	18.70	-1.17	0.442	24.0	24.0
29.10.2022	68.75	47.51	21.24	23.10	23.35	-1.06	0.490	24.0	24.0
30.10.2022	68.40	47.52	20.88	23.36	23.61	-1.04	0.487	24.0	24.0
31.10.2022	68.54	47.52	21.03	23.05	23.29	-1.05	0.484	24.0	24.0
Средние:	68.03	46.34	21.69	---	---	-1.07	---	---	---
Итого:	---	---	---	636.75	643.53	---	13.622	744.0	744.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
30.09.2022	41.83	42.01	0.367	738.1	2219.1
31.10.2022	678.58	685.54	13.990	1482.1	2963.1
Итого:	636.75	643.53	13.622	744.0	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.11.2022 0:00:00 - 30.11.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 19 (4 МКД "Заречная УК")
Прибор: ИМ2300 А-Е Заводской номер: СА537
Точка измерения: Узел 1; Ресурс: ТС

Подача: Счетчик воды:
Обратка: ПРИМ SN 10174
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Датчик температуры:
КТПТР-06 SN 4276
КТПТР-06 SN 4276а

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.11.2022	68.26	47.96	20.29	23.80	24.04	-1.01	0.482	24.0	24.0
02.11.2022	68.14	48.18	19.96	24.42	24.66	-1.00	0.486	24.0	24.0
03.11.2022	68.53	49.99	18.54	27.10	27.36	-0.94	0.501	24.0	24.0
04.11.2022	68.35	49.55	18.80	26.34	26.59	-0.95	0.495	24.0	24.0
05.11.2022	69.84	49.72	20.12	25.29	25.56	-1.03	0.508	24.0	24.0
06.11.2022	70.26	49.61	20.65	24.87	25.13	-1.06	0.513	24.0	24.0
07.11.2022	69.49	48.56	20.93	24.20	24.46	-1.06	0.506	24.0	24.0
08.11.2022	70.67	49.73	20.94	24.70	24.97	-1.08	0.517	24.0	24.0
09.11.2022	70.45	49.69	20.76	25.09	25.36	-1.07	0.520	24.0	24.0
10.11.2022	69.67	50.49	19.18	27.34	27.61	-0.98	0.522	24.0	24.0
11.11.2022	69.04	50.74	18.30	28.34	28.61	-0.93	0.517	24.0	24.0
12.11.2022	69.35	52.15	17.19	30.68	30.95	-0.89	0.527	24.0	24.0
13.11.2022	69.15	52.19	16.96	30.49	30.76	-0.88	0.516	24.0	24.0
14.11.2022	68.95	51.51	17.44	29.17	29.43	-0.90	0.507	24.0	24.0
15.11.2022	72.10	51.18	20.93	25.85	26.13	-1.09	0.539	24.0	24.0
16.11.2022	82.40	56.52	25.88	26.20	26.60	-1.49	0.678	24.0	24.0
17.11.2022	86.74	58.68	28.06	26.42	26.86	-1.67	0.742	24.0	24.0
18.11.2022	94.27	62.07	32.20	26.23	26.76	-2.02	0.846	24.0	24.0
19.11.2022	100.25	61.34	38.91	21.54	22.07	-2.44	0.818	24.0	24.0
20.11.2022	97.49	53.34	44.15	16.28	16.73	-2.69	0.720	24.0	24.0
21.11.2022	96.95	53.02	43.93	16.45	16.89	-2.67	0.723	24.0	24.0
22.11.2022	95.82	53.14	42.68	16.86	17.30	-2.58	0.720	24.0	24.0
23.11.2022	90.36	51.46	38.90	17.12	17.51	-2.27	0.666	24.0	24.0
24.11.2022	86.31	48.69	37.62	16.31	16.65	-2.11	0.613	24.0	24.0
25.11.2022	87.22	48.97	38.25	16.45	16.81	-2.16	0.629	24.0	24.0
26.11.2022	92.43	50.91	41.52	16.42	16.83	-2.44	0.682	24.0	24.0
27.11.2022	93.61	50.65	42.96	16.03	16.44	-2.53	0.689	24.0	24.0
28.11.2022	93.95	50.65	43.29	15.99	16.40	-2.55	0.693	24.0	24.0
29.11.2022	92.95	50.49	42.46	15.96	16.37	-2.49	0.678	24.0	24.0
30.11.2022	96.56	54.80	41.76	19.13	19.62	-2.53	0.791	24.0	24.0
Средние:	80.98	51.87	29.12	---	---	-1.65	---	---	---
Итого:	---	---	---	681.06	691.46	---	18.346	720.0	720.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.10.2022	678.58	685.54	13.990	1482.1	2963.1
30.11.2022	1359.64	1377.00	32.336	2202.1	3683.1
Итого:	681.06	691.46	18.346	720.0	720.0

Представитель абонента

Представитель энергоснабжающей организации