

Отчет о суточных параметрах
(01.08.2022 0:00:00 - 31.08.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 31 (4 МКД УК "Заречная")
Прибор: ИМ2300 А-Е Заводской номер: СА531
Точка измерения: Узел 1; Ресурс: ТС

Подача:
Обратка:
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:
ПРИМ SN 15327
ПРИМ SN 15328

Датчик температуры:
КТПТР-06 SN 4269
КТПТР-06 SN 4269a

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.08.2022	71.81	65.00	6.81	49.15	49.42	-0.54	0.334	24.0	24.0
02.08.2022	71.88	65.26	6.62	48.77	49.01	-0.48	0.311	24.0	24.0
03.08.2022	63.21	55.70	7.51	33.66	33.86	-0.57	0.243	24.0	24.0
04.08.2022	63.57	55.83	7.74	38.98	39.18	-0.52	0.309	24.0	24.0
05.08.2022	64.54	57.74	6.80	41.87	42.01	-0.34	0.278	24.0	24.0
06.08.2022	66.06	59.91	6.15	46.82	47.03	-0.46	0.285	24.0	24.0
07.08.2022	67.67	60.77	6.90	51.59	51.90	-0.61	0.344	24.0	24.0
08.08.2022	68.63	61.78	6.85	53.42	53.77	-0.66	0.358	24.0	24.0
09.08.2022	57.05	62.40	-5.35	42.20	42.81	-1.43	0.153	13.0	24.0
10.08.2022	34.08	30.67	3.41	3.81	3.82	-0.34	0.039	14.1	24.0
11.08.2022	27.00	22.85	4.15	0.70	0.70	0.28	0.008	11.7	24.0
12.08.2022	23.09	25.09	-2.00	0.00	0.00	---	0.000	0.0	24.0
13.08.2022	23.24	22.49	0.75	0.00	0.00	---	0.000	0.0	24.0
14.08.2022	22.68	22.00	0.68	0.00	0.00	---	0.000	0.0	24.0
15.08.2022	21.93	21.10	0.83	0.00	0.00	---	0.000	0.0	24.0
16.08.2022	21.50	20.75	0.75	0.00	0.00	---	0.000	0.0	24.0
17.08.2022	21.06	20.40	0.66	0.00	0.00	---	0.000	0.0	24.0
18.08.2022	20.80	20.19	0.61	0.00	0.00	---	0.000	0.0	24.0
19.08.2022	20.38	20.03	0.35	0.05	0.05	0.29	0.000	0.2	24.0
20.08.2022	19.76	19.88	-0.12	0.03	0.02	38.21	0.000	0.3	24.0
21.08.2022	20.00	19.59	0.41	0.00	0.00	---	0.000	0.0	24.0
22.08.2022	20.16	19.81	0.35	0.37	0.13	97.92	0.000	6.2	24.0
23.08.2022	23.16	21.71	1.45	5.96	5.92	0.66	0.033	18.6	24.0
24.08.2022	58.54	50.79	7.75	31.97	32.21	-0.76	0.245	22.9	24.0
25.08.2022	64.10	57.58	6.52	38.11	38.20	-0.24	0.254	24.0	24.0
26.08.2022	66.89	60.33	6.57	46.13	46.16	-0.08	0.300	24.0	24.0
27.08.2022	68.06	60.50	7.56	45.91	46.01	-0.21	0.348	24.0	24.0
28.08.2022	68.56	66.14	2.42	46.65	47.03	-0.80	0.113	24.0	24.0
29.08.2022	70.11	67.57	2.53	46.04	46.49	-0.96	0.116	24.0	24.0
30.08.2022	76.19	73.54	2.66	51.40	52.05	-1.26	0.137	23.5	24.0
31.08.2022	74.86	72.61	2.25	52.34	52.66	-0.61	0.118	23.4	24.0
Средние:	47.12	43.87	3.24	---	---	4.08	---	---	---
Итого:	---	---	---	775.94	780.45	---	4.325	445.8	744.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.07.2022	1046.18	1057.33	10.316	761.2	970.5
31.08.2022	1822.11	1837.78	14.642	1207.0	1714.5
Итого:	775.94	780.45	4.325	445.8	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.09.2022 0:00:00 - 08.10.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 31 (4 МКД УК "Заречная")
Прибор: ИМ2300 А-Е Заводской номер: СА531
Точка измерения: Узел 1; Ресурс: ТС

Подача: Счетчик воды:
ПРИМ SN 15327
Обратка: ПРИМ SN 15328

Датчик температуры:
КТПТР-06 SN 4269
КТПТР-06 SN 4269а

Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.09.2022	64.70	63.34	1.37	28.14	28.22	-0.29	0.046	24.0	24.0
02.09.2022	65.94	64.98	0.96	20.31	20.34	-0.11	0.020	24.0	24.0
03.09.2022	70.37	69.27	1.10	20.71	20.85	-0.67	0.023	24.0	24.0
04.09.2022	50.07	50.97	-0.90	12.36	12.30	0.48	0.012	11.7	24.0
05.09.2022	22.84	21.50	1.34	0.24	0.00	200.00	0.000	4.0	24.0
06.09.2022	21.21	19.96	1.25	0.81	0.00	199.93	0.001	11.9	24.0
07.09.2022	19.67	18.50	1.16	0.00	0.00	79.25	0.000	0.0	24.0
08.09.2022	18.46	17.66	0.80	0.00	0.00	---	0.000	0.0	24.0
09.09.2022	17.89	17.25	0.64	0.00	0.00	---	0.000	0.0	24.0
10.09.2022	49.67	43.47	6.21	25.62	25.81	-0.75	0.266	13.6	24.0
11.09.2022	74.71	67.33	7.37	53.63	54.11	-0.90	0.387	24.0	24.0
12.09.2022	72.51	62.66	9.85	44.58	44.79	-0.48	0.417	24.0	24.0
13.09.2022	67.09	59.97	7.12	39.11	39.27	-0.40	0.276	20.9	24.0
14.09.2022	45.24	42.38	2.86	22.64	22.68	-0.17	0.078	20.4	24.0
15.09.2022	20.79	19.70	1.09	1.44	1.44	-0.02	0.002	24.0	24.0
16.09.2022	19.54	18.87	0.67	0.65	0.67	-2.89	0.001	10.9	24.0
17.09.2022	18.93	18.44	0.49	0.00	0.04	-187.46	0.000	0.0	24.0
18.09.2022	31.90	28.81	3.09	13.71	13.81	-0.68	0.143	6.2	24.0
19.09.2022	69.82	61.45	8.37	49.25	50.00	-1.51	0.396	24.0	24.0
20.09.2022	65.74	56.83	8.90	39.64	40.19	-1.40	0.318	24.0	24.0
21.09.2022	65.42	49.85	15.57	41.74	41.18	1.35	0.683	23.9	24.0
22.09.2022	64.90	35.43	29.47	45.45	45.02	0.96	1.329	24.0	24.0
23.09.2022	60.58	32.83	27.75	40.17	39.78	0.97	1.120	24.0	24.0
24.09.2022	66.12	36.75	29.37	48.89	48.44	0.93	1.431	24.0	24.0
25.09.2022	63.59	36.76	26.83	50.41	50.02	0.78	1.353	24.0	24.0
26.09.2022	65.76	37.45	28.32	53.01	52.54	0.88	1.491	24.0	24.0
27.09.2022	65.06	35.34	29.73	47.25	46.74	1.10	1.399	24.0	24.0
28.09.2022	67.23	40.44	26.78	67.69	67.50	0.29	1.805	24.0	24.0
29.09.2022	68.87	32.64	36.23	66.08	65.97	0.17	2.368	24.0	24.0
30.09.2022	67.93	28.92	39.01	61.27	61.13	0.22	2.392	24.0	24.0
01.10.2022	68.25	39.10	29.15	59.32	59.08	0.41	1.725	24.0	24.0
02.10.2022	67.60	38.60	28.99	59.83	59.51	0.53	1.733	24.0	24.0
03.10.2022	68.45	40.81	27.63	64.48	64.19	0.45	1.776	24.0	24.0
04.10.2022	68.64	42.14	26.50	65.78	65.51	0.41	1.738	24.0	24.0
05.10.2022	68.46	41.79	26.67	65.38	65.10	0.42	1.736	24.0	24.0
06.10.2022	67.76	41.55	26.21	61.75	61.45	0.49	1.619	24.0	24.0
07.10.2022	---	---	---	---	---	---	---	---	---
08.10.2022	---	---	---	---	---	---	---	---	---
Средние:	54.21	39.83	14.39	---	---	8.12	---	---	---
Итого:	---	---	---	1271.32	1267.68	---	28.083	675.6	864.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.08.2022	1822.11	1837.78	14.642	1207.0	1714.5
06.10.2022	3093.44	3105.46	42.724	1882.6	2578.5
Итого:	1271.32	1267.68	28.083	675.6	864.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.10.2022 0:00:00 - 31.10.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 31 (4 МКД УК "Заречная")
Прибор: ИМ2300 А-Е Заводской номер: СА531
Точка измерения: Узел 1; Ресурс: ТС

Подача:
Обратка:
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:
ПРИМ SN 15327
ПРИМ SN 15328

Датчик температуры:
КТПТР-06 SN 4269
КТПТР-06 SN 4269a

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.10.2022	68.25	39.10	29.15	59.32	59.08	0.41	1.725	24.0	24.0
02.10.2022	67.60	38.60	28.99	59.83	59.51	0.53	1.733	24.0	24.0
03.10.2022	68.45	40.81	27.63	64.48	64.19	0.45	1.776	24.0	24.0
04.10.2022	68.64	42.14	26.50	65.78	65.51	0.41	1.738	24.0	24.0
05.10.2022	68.46	41.79	26.67	65.38	65.10	0.42	1.736	24.0	24.0
06.10.2022	67.76	41.55	26.21	61.75	61.45	0.49	1.619	24.0	24.0
07.10.2022	67.56	42.00	25.56	61.28	61.54	-0.42	1.564	24.0	24.0
08.10.2022	68.25	42.28	25.98	65.33	65.59	-0.40	1.694	24.0	24.0
09.10.2022	68.98	40.99	27.99	61.94	62.15	-0.34	1.734	24.0	24.0
10.10.2022	69.03	41.05	27.98	64.36	64.63	-0.43	1.795	24.0	24.0
11.10.2022	68.42	41.50	26.92	63.46	63.63	-0.26	1.702	24.0	24.0
12.10.2022	69.23	43.10	26.14	58.45	57.22	2.13	1.532	24.0	24.0
13.10.2022	68.16	39.23	28.93	56.75	56.60	0.27	1.635	24.0	24.0
14.10.2022	68.53	41.58	26.95	64.16	63.95	0.32	1.725	24.0	24.0
15.10.2022	68.19	40.17	28.02	59.85	59.58	0.46	1.669	24.0	24.0
16.10.2022	68.73	39.85	28.88	58.69	58.41	0.48	1.691	24.0	24.0
17.10.2022	67.98	37.60	30.39	54.35	54.05	0.55	1.645	23.9	23.9
18.10.2022	68.08	39.13	28.95	56.59	56.27	0.56	1.634	24.0	24.0
19.10.2022	68.08	38.09	29.99	56.08	55.75	0.60	1.676	24.0	24.0
20.10.2022	67.77	37.92	29.85	53.02	52.67	0.67	1.574	24.0	24.0
21.10.2022	67.31	36.19	31.13	48.82	48.46	0.76	1.519	24.0	24.0
22.10.2022	68.28	37.15	31.13	52.80	52.44	0.69	1.640	24.0	24.0
23.10.2022	67.73	36.79	30.94	53.97	53.63	0.64	1.668	24.0	24.0
24.10.2022	69.95	37.82	32.13	59.16	58.83	0.56	1.898	24.0	24.0
25.10.2022	69.07	38.62	30.44	59.35	59.02	0.55	1.797	24.0	24.0
26.10.2022	67.67	36.02	31.65	52.96	52.59	0.70	1.672	24.0	24.0
27.10.2022	68.05	34.96	33.08	50.39	50.03	0.72	1.659	24.0	24.0
28.10.2022	66.92	31.91	35.01	44.43	43.97	1.02	1.542	24.0	24.0
29.10.2022	67.53	35.33	32.20	54.84	54.50	0.63	1.762	24.0	24.0
30.10.2022	67.35	35.66	31.68	55.23	54.88	0.65	1.747	24.0	24.0
31.10.2022	67.41	34.54	32.86	54.52	54.14	0.69	1.784	24.0	24.0
Средние:	68.17	38.82	29.35	---	---	0.47	---	---	---
Итого:	---	---	---	1797.32	1789.36	---	52.285	743.9	743.9

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
30.09.2022	2716.91	2730.61	32.398	1738.6	2434.5
31.10.2022	4514.22	4519.98	84.683	2482.5	3178.4
Итого:	1797.32	1789.37	52.285	743.9	743.9

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.11.2022 0:00:00 - 30.11.2022 0:00:00)

Объект: Пермь г, Закамская ул, д. 31 (4 МКД УК "Заречная")
Прибор: ИМ2300 А-Е Заводской номер: СА531
Точка измерения: Узел 1; Ресурс: ТС

Подача:
Обратка:
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:
ПРИМ SN 15327
ПРИМ SN 15328

Датчик температуры:
КТПТР-06 SN 4269
КТПТР-06 SN 4269а

Дата	T1	T2	dt	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т		Гкал	ч	ч
01.11.2022	67.14	35.99	31.16	56.41	56.04	0.66	1.754	24.0	24.0
02.11.2022	67.04	36.51	30.52	57.69	57.34	0.62	1.759	24.0	24.0
03.11.2022	67.55	38.72	28.83	63.71	63.41	0.47	1.832	24.0	24.0
04.11.2022	67.31	38.56	28.75	61.71	61.39	0.53	1.769	24.0	24.0
05.11.2022	68.66	38.09	30.57	59.48	59.13	0.59	1.815	24.0	24.0
06.11.2022	69.20	38.10	31.10	58.31	57.95	0.62	1.808	24.0	24.0
07.11.2022	68.36	35.66	32.70	56.75	56.38	0.65	1.851	24.0	24.0
08.11.2022	69.61	37.51	32.10	58.14	57.75	0.67	1.863	24.0	24.0
09.11.2022	69.32	38.16	31.16	59.11	58.72	0.67	1.840	24.0	24.0
10.11.2022	69.62	39.53	30.09	64.95	64.61	0.53	1.952	24.0	24.0
11.11.2022	70.11	39.68	30.43	66.68	66.34	0.51	2.019	24.0	24.0
12.11.2022	70.42	42.15	28.27	72.11	71.81	0.41	2.035	24.0	24.0
13.11.2022	70.22	42.08	28.14	71.80	71.55	0.36	2.015	24.0	24.0
14.11.2022	70.26	40.32	29.94	68.60	68.32	0.40	2.041	24.0	24.0
15.11.2022	74.00	40.26	33.74	60.89	60.55	0.56	2.048	24.0	24.0
16.11.2022	84.05	43.59	40.45	62.23	61.84	0.64	2.518	24.0	24.0
17.11.2022	89.23	45.20	44.02	62.88	62.44	0.71	2.768	24.0	24.0
18.11.2022	96.99	47.48	49.50	62.85	62.40	0.73	3.117	24.0	24.0
19.11.2022	102.79	44.57	58.22	66.37	65.61	1.15	3.865	24.0	24.0
20.11.2022	100.48	49.23	51.25	65.38	64.47	1.39	3.356	24.0	24.0
21.11.2022	100.05	49.61	50.43	66.37	65.35	1.56	3.352	24.0	24.0
22.11.2022	98.66	49.59	49.07	67.64	66.55	1.62	3.321	24.0	24.0
23.11.2022	92.43	47.98	44.45	68.33	67.31	1.51	3.038	24.0	24.0
24.11.2022	88.64	44.68	43.95	64.96	63.96	1.55	2.852	24.0	24.0
25.11.2022	90.48	45.92	44.56	65.85	64.82	1.57	2.934	24.0	24.0
26.11.2022	95.77	47.39	48.38	66.22	64.89	2.03	3.206	24.0	24.0
27.11.2022	96.99	48.45	48.55	65.89	63.52	3.66	3.200	24.0	24.0
28.11.2022	97.14	46.68	50.45	63.72	63.57	0.24	3.218	24.0	24.0
29.11.2022	95.64	43.68	51.96	63.57	63.40	0.27	3.298	24.0	24.0
30.11.2022	98.00	40.41	57.59	60.48	60.11	0.61	3.473	24.0	24.0
Средние:	82.20	42.53	39.68	---	---	0.92	---	---	---
Итого:	---	---	---	1909.09	1891.52	---	75.915	720.0	720.0

Дата	M1	M2	Q1	TWork	QntHIP
	т	т	Гкал	ч	ч
31.10.2022	4514.22	4519.98	84.683	2482.5	3178.4
30.11.2022	6423.32	6411.50	160.598	3202.5	3898.4
Итого:	1909.09	1891.52	75.915	720.0	720.0

Представитель абонента

Представитель энергоснабжающей организации