

Отчет о суточных параметрах  
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Торговая ул, д. 20 (4 МКД ООО "ЗУК")  
Прибор: ИМ2300 А-Е Заводской номер: СА518  
Точка измерения: Узел 1; Ресурс: ТС

Подача: Счетчик воды:  
Обратка: ПРИМ SN 251255  
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Датчик температуры:  
КТПТР-06 SN 3422  
КТПТР-06 SN 3422 А

Дата	T1	T2	dt	Qo1	Qo2	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	м3/ч	м3/ч	т	т		Гкал	ч	ч
01.01.2024	101.35	46.58	54.76	6.09	5.74	139.90	136.26	2.63	7.679	24.0	24.0
02.01.2024	102.38	48.07	54.31	6.46	6.13	148.40	145.53	1.95	8.075	24.0	24.0
03.01.2024	107.71	51.11	56.60	6.30	5.96	144.20	141.23	2.08	8.177	24.0	24.0
04.01.2024	111.88	52.15	59.73	6.32	5.96	144.05	141.25	1.97	8.628	24.0	24.0
05.01.2024	109.73	52.26	57.47	6.47	6.11	147.79	144.82	2.03	8.519	24.0	24.0
06.01.2024	111.33	53.56	57.77	6.65	6.27	151.62	148.45	2.11	8.786	24.0	24.0
07.01.2024	111.31	51.85	59.47	6.25	5.90	142.49	139.74	1.94	8.493	24.0	24.0
08.01.2024	112.29	53.08	59.21	6.43	6.07	146.60	143.76	1.96	8.709	24.0	24.0
09.01.2024	111.94	51.75	60.19	6.35	5.96	144.69	141.20	2.44	8.735	24.0	24.0
10.01.2024	111.04	52.63	58.41	6.46	6.09	147.43	144.28	2.16	8.635	24.0	24.0
11.01.2024	110.17	51.52	58.65	6.24	5.88	142.48	139.26	2.29	8.371	24.0	24.0
12.01.2024	110.35	51.36	58.99	6.23	5.88	142.20	139.32	2.04	8.410	24.0	24.0
13.01.2024	109.69	52.09	57.60	6.36	6.00	145.21	142.21	2.09	8.385	24.0	24.0
14.01.2024	109.16	50.21	58.94	6.08	5.72	138.85	135.76	2.26	8.199	24.0	24.0
15.01.2024	109.68	50.64	59.05	6.32	5.96	144.24	141.25	2.09	8.542	24.0	24.0
16.01.2024	101.75	49.04	52.71	6.30	5.98	144.66	141.84	1.97	7.637	24.0	24.0
17.01.2024	91.65	45.00	46.66	5.95	5.69	137.76	135.18	1.89	6.430	24.0	24.0
18.01.2024	84.92	41.85	43.07	5.77	5.52	134.09	131.25	2.14	5.728	24.0	24.0
19.01.2024	84.75	44.29	40.45	6.51	6.22	151.43	147.83	2.41	6.122	24.0	24.0
20.01.2024	86.34	44.57	41.78	6.44	6.11	149.75	145.14	3.13	6.253	24.0	24.0
21.01.2024	81.88	35.99	45.89	4.92	4.63	114.63	110.25	3.89	4.881	24.0	24.0
22.01.2024	76.69	38.02	38.68	5.94	5.58	138.81	132.94	4.32	5.347	24.0	24.0
23.01.2024	87.84	44.04	43.80	6.29	5.95	146.02	141.50	3.14	6.385	24.0	24.0
24.01.2024	91.71	44.77	46.93	6.35	5.95	146.96	141.36	3.88	6.905	24.0	24.0
25.01.2024	92.13	47.97	44.16	6.86	6.36	158.68	151.04	4.93	6.990	24.0	24.0
26.01.2024	91.19	54.71	36.48	7.13	6.63	165.02	156.82	5.10	6.024	24.0	24.0
27.01.2024	92.09	51.95	40.14	7.08	6.66	163.77	157.89	3.65	6.561	24.0	24.0
28.01.2024	91.24	47.75	43.50	6.56	6.19	151.98	147.03	3.31	6.610	24.0	24.0
29.01.2024	88.72	46.04	42.68	6.32	5.91	146.63	140.48	4.28	6.247	24.0	24.0
30.01.2024	85.58	44.77	40.81	6.22	5.82	144.53	138.37	4.35	5.896	24.0	24.0
31.01.2024	82.81	44.81	38.00	6.44	6.05	150.02	143.85	4.20	5.698	24.0	24.0
Средние:	98.43	48.21	50.22	6.32	5.96	---	---	2.86	---	---	---
Итого:	---	---	---	---	---	4514.87	4387.09	---	226.056	744.0	744.0

Дата	Gm_itog1	Gm_itog2	Qt_itog1	tm1_itog	ts1_itog
	т	т	Гкал	ч	ч
31.12.2023	168034.38	178420.14	4722.622	32813.8	38559.6
31.01.2024	172549.23	182807.23	4948.679	33557.8	39303.6
Итого:	4514.86	4387.09	226.057	744.0	744.0

Представитель абонента

Представитель энергоснабжающей организации