

Отчет о суточных параметрах  
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермь г, Торговая ул, д. 20 (4 МКД ООО "ЗУК")  
Прибор: ИМ2300 А-Е Заводской номер: СА518  
Точка измерения: Узел 1; Ресурс: ТС

Подача: Счетчик воды:  
Обратка: ПРИМ SN 251255  
Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Датчик температуры:  
КТПТР-06 SN 3422  
КТПТР-06 SN 3422 А

Дата	T1	T2	dt	Qo1	Qo2	Gm1	Gm2	%	Qt1	tm1	ts1
	°C	°C	°C	м3/ч	м3/ч	т	т		Гкал	ч	ч
01.03.2024	78.68	41.86	36.83	6.04	5.60	141.10	133.21	5.75	5.189	24.0	24.0
02.03.2024	78.00	42.54	35.46	6.19	5.84	144.65	138.89	4.07	5.124	24.0	24.0
03.03.2024	76.92	42.46	34.46	6.36	5.90	148.59	140.36	5.70	5.114	24.0	24.0
04.03.2024	75.82	41.42	34.40	6.32	5.84	147.85	138.92	6.23	5.073	24.0	24.0
05.03.2024	79.46	44.55	34.91	6.76	6.27	157.78	149.11	5.65	5.506	24.0	24.0
06.03.2024	75.12	41.80	33.32	6.12	5.73	143.34	136.39	4.97	4.766	24.0	24.0
07.03.2024	84.62	43.27	41.35	6.11	5.70	142.12	135.45	4.80	5.887	24.0	24.0
08.03.2024	88.65	46.80	41.84	6.52	5.96	151.17	141.50	6.60	6.325	24.0	24.0
09.03.2024	81.24	44.21	37.04	6.48	6.02	150.99	143.05	5.40	5.589	24.0	24.0
10.03.2024	77.90	42.24	35.66	6.17	5.80	144.24	137.90	4.49	5.137	24.0	24.0
11.03.2024	87.12	44.19	42.93	6.20	5.77	143.98	137.27	4.77	6.195	24.0	24.0
12.03.2024	93.87	48.03	45.84	6.38	6.02	147.38	142.80	3.16	6.755	24.0	24.0
13.03.2024	90.96	47.73	43.23	6.46	6.10	149.65	144.74	3.34	6.466	24.0	24.0
14.03.2024	86.16	44.76	41.40	6.18	5.92	143.63	140.79	2.00	5.932	23.7	24.0
15.03.2024	78.51	44.24	34.27	6.61	6.27	154.38	149.03	3.52	5.280	24.0	24.0
16.03.2024	75.11	41.92	33.18	6.43	6.14	150.49	146.06	2.99	4.984	24.0	24.0
17.03.2024	75.02	42.25	32.77	6.57	6.28	153.82	149.41	2.91	5.035	24.0	24.0
18.03.2024	75.12	42.01	33.11	6.66	6.34	155.90	150.82	3.31	5.154	24.0	24.0
19.03.2024	74.49	42.58	31.92	6.78	6.45	158.67	153.48	3.33	5.048	24.0	24.0
20.03.2024	73.53	41.36	32.17	6.47	6.11	151.56	145.40	4.15	4.881	24.0	24.0
21.03.2024	71.52	41.45	30.07	6.51	6.22	152.67	148.04	3.08	4.574	24.0	24.0
22.03.2024	67.73	38.81	28.93	6.20	5.94	145.85	141.51	3.02	4.215	24.0	24.0
23.03.2024	70.58	41.59	28.99	6.83	6.51	160.30	155.05	3.32	4.644	24.0	24.0
24.03.2024	71.76	41.94	29.82	6.93	6.61	162.60	157.30	3.31	4.844	24.0	24.0
25.03.2024	68.48	39.27	29.21	6.30	5.98	147.94	142.46	3.78	4.306	24.0	24.0
26.03.2024	67.72	38.60	29.12	6.15	5.85	144.53	139.33	3.67	4.200	24.0	24.0
27.03.2024	68.30	39.81	28.50	6.54	6.22	153.76	148.08	3.77	4.373	24.0	24.0
28.03.2024	67.88	39.22	28.66	6.37	6.06	149.69	144.25	3.70	4.272	24.0	24.0
29.03.2024	70.63	38.48	32.15	5.99	5.66	140.54	134.78	4.18	4.514	24.0	24.0
30.03.2024	73.58	40.35	33.22	6.18	5.84	144.77	139.13	3.97	4.803	24.0	24.0
31.03.2024	69.19	38.93	30.26	6.13	5.83	144.09	138.96	3.62	4.354	24.0	24.0
Средние:	76.57	42.22	34.36	6.39	6.02	---	---	4.08	---	---	---
Итого:	---	---	---	---	---	4628.05	4443.48	---	158.537	743.7	744.0

Дата	Gm_itog1	Gm_itog2	Qt_itog1	tm1_itog	ts1_itog
	т	т	Гкал	ч	ч
29.02.2024	176779.48	186866.05	5137.195	34253.8	39999.6
31.03.2024	181263.44	191170.57	5291.379	34973.5	40719.6
Итого:	4483.96	4304.53	154.184	719.7	720.0

Представитель абонента

Представитель энергоснабжающей организации