

Отчет о суточных параметрах
(01.10.2023 0:00:00 - 31.10.2023 0:00:00)

Объект: Пермь г, Волгодонская ул, д. 18 (4 МКД "Заречная УК")
Прибор: ТМК-Н13 Заводской номер: 1182
Точка измерения: ТС1; Ресурс: ТС

Схема измерений: Закрытая система, ПР в подающем ТП и обратном ТП (измерение Q по G1)

| Дата | t1 | t2 | M1 | M2 | P1 | P2 | Qo | txв | ВНР | NS |
|------------|-------|-------|---------|---------|---------|---------|--------|------|-------|----|
| | °C | °C | т | т | кгс/см2 | кгс/см2 | Гкал | °C | ч | |
| 01.10.2023 | 18.70 | 18.90 | 34.19 | 159.83 | 5.00 | 5.00 | 0.000 | 5.00 | 0.0 | * |
| 02.10.2023 | 25.40 | 24.20 | 116.68 | 180.65 | 5.00 | 5.00 | 0.276 | 5.00 | 12.2 | * |
| 03.10.2023 | 29.00 | 27.50 | 240.40 | 240.50 | 5.00 | 5.00 | 0.368 | 5.00 | 23.7 | * |
| 04.10.2023 | 40.90 | 35.80 | 184.35 | 184.45 | 5.00 | 5.00 | 0.934 | 5.00 | 24.0 | |
| 05.10.2023 | 42.80 | 37.10 | 175.88 | 175.93 | 5.00 | 5.00 | 1.002 | 5.00 | 24.0 | |
| 06.10.2023 | 43.10 | 37.30 | 174.81 | 174.89 | 5.00 | 5.00 | 1.012 | 5.00 | 24.0 | |
| 07.10.2023 | 41.60 | 36.20 | 172.83 | 172.87 | 5.00 | 5.00 | 0.927 | 5.00 | 23.6 | * |
| 08.10.2023 | 41.30 | 35.90 | 171.70 | 171.69 | 5.00 | 5.00 | 0.923 | 5.00 | 24.0 | |
| 09.10.2023 | 45.00 | 38.40 | 170.66 | 170.84 | 5.00 | 5.00 | 1.122 | 5.00 | 24.0 | |
| 10.10.2023 | 44.30 | 37.80 | 170.30 | 170.45 | 5.00 | 5.00 | 1.101 | 5.00 | 24.0 | |
| 11.10.2023 | 46.90 | 39.70 | 172.87 | 173.04 | 5.00 | 5.00 | 1.239 | 5.00 | 24.0 | |
| 12.10.2023 | 48.60 | 40.80 | 171.56 | 171.73 | 5.00 | 5.00 | 1.345 | 5.00 | 24.0 | |
| 13.10.2023 | 44.60 | 38.00 | 167.98 | 168.00 | 5.00 | 5.00 | 1.107 | 5.00 | 24.0 | |
| 14.10.2023 | 45.00 | 38.10 | 166.65 | 166.75 | 5.00 | 5.00 | 1.142 | 5.00 | 24.0 | |
| 15.10.2023 | 44.80 | 38.10 | 166.63 | 166.68 | 5.00 | 5.00 | 1.115 | 5.00 | 24.0 | |
| 16.10.2023 | 37.70 | 33.50 | 166.74 | 166.60 | 5.00 | 5.00 | 0.710 | 5.00 | 24.0 | |
| 17.10.2023 | 37.90 | 33.50 | 166.58 | 166.46 | 5.00 | 5.00 | 0.726 | 5.00 | 24.0 | * |
| 18.10.2023 | 44.90 | 38.00 | 166.49 | 166.55 | 5.00 | 5.00 | 1.148 | 5.00 | 24.0 | |
| 19.10.2023 | 46.90 | 39.40 | 166.44 | 166.52 | 5.00 | 5.00 | 1.246 | 5.00 | 24.0 | |
| 20.10.2023 | 46.80 | 39.30 | 166.42 | 166.50 | 5.00 | 5.00 | 1.240 | 5.00 | 24.0 | |
| 21.10.2023 | 47.30 | 39.60 | 166.42 | 166.38 | 5.00 | 5.00 | 1.295 | 5.00 | 24.0 | |
| 22.10.2023 | 47.30 | 39.10 | 166.60 | 166.72 | 5.00 | 5.00 | 1.359 | 5.00 | 24.0 | |
| 23.10.2023 | 47.00 | 38.50 | 167.20 | 166.98 | 5.00 | 5.00 | 1.411 | 5.00 | 24.0 | * |
| 24.10.2023 | 47.10 | 38.30 | 168.07 | 168.21 | 5.00 | 5.00 | 1.477 | 5.00 | 24.0 | |
| 25.10.2023 | 49.90 | 39.60 | 168.44 | 168.72 | 5.00 | 5.00 | 1.719 | 5.00 | 24.0 | |
| 26.10.2023 | 51.60 | 40.70 | 168.44 | 168.68 | 5.00 | 5.00 | 1.837 | 5.00 | 24.0 | |
| 27.10.2023 | 54.30 | 42.40 | 168.47 | 168.86 | 5.00 | 5.00 | 2.008 | 5.00 | 24.0 | |
| 28.10.2023 | 54.30 | 42.30 | 168.44 | 168.85 | 5.00 | 5.00 | 2.007 | 5.00 | 24.0 | |
| 29.10.2023 | 52.80 | 41.60 | 168.47 | 168.82 | 5.00 | 5.00 | 1.883 | 5.00 | 24.0 | |
| 30.10.2023 | 53.00 | 41.70 | 168.65 | 168.98 | 5.00 | 5.00 | 1.904 | 5.00 | 24.0 | |
| 31.10.2023 | 53.50 | 42.10 | 169.23 | 169.58 | 5.00 | 5.00 | 1.916 | 5.00 | 24.0 | |
| Средние: | 44.33 | 37.21 | --- | --- | 5.00 | 5.00 | --- | 5.00 | --- | |
| Итого: | --- | --- | 5138.61 | 5331.72 | --- | --- | 37.496 | --- | 707.5 | |

| Дата | M1 | M2 | Qo | ВНР |
|------------|-----------|-----------|----------|---------|
| | т | т | Гкал | ч |
| 30.09.2023 | 309398.31 | 450008.62 | 3121.862 | 55446.3 |
| 31.10.2023 | 314536.92 | 455340.34 | 3159.358 | 56153.8 |
| Итого: | 5138.61 | 5331.72 | 37.496 | 707.5 |

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.10.2023 0:00:00 - 31.10.2023 0:00:00)

Объект: Пермь г, Волгодонская ул, д. 18 (4 МКД "Заречная УК")
Прибор: ТМК-Н13 Заводской номер: 1182
Точка измерения: ТС2; Ресурс: ГВС

Схема измерений: ГВС

| Дата | t3 | M3 | P3 | Qo | txв | BNP | NS |
|------------|-------|--------|---------|--------|------|-------|----|
| | °C | т | кгс/см2 | Гкал | °C | ч | |
| 01.10.2023 | 59.10 | 6.88 | 5.00 | 0.387 | 5.00 | 24.0 | * |
| 02.10.2023 | 57.10 | 6.70 | 5.00 | 0.361 | 5.00 | 24.0 | * |
| 03.10.2023 | 54.20 | 7.30 | 5.00 | 0.375 | 5.00 | 24.0 | * |
| 04.10.2023 | 55.60 | 6.43 | 5.00 | 0.339 | 5.00 | 24.0 | * |
| 05.10.2023 | 56.10 | 5.62 | 5.00 | 0.302 | 5.00 | 24.0 | * |
| 06.10.2023 | 57.80 | 5.93 | 5.00 | 0.328 | 5.00 | 24.0 | * |
| 07.10.2023 | 58.10 | 6.22 | 5.00 | 0.346 | 5.00 | 24.0 | * |
| 08.10.2023 | 59.10 | 6.78 | 5.00 | 0.380 | 5.00 | 24.0 | * |
| 09.10.2023 | 58.60 | 6.71 | 5.00 | 0.369 | 5.00 | 24.0 | * |
| 10.10.2023 | 55.70 | 5.96 | 5.00 | 0.317 | 5.00 | 24.0 | * |
| 11.10.2023 | 58.40 | 6.82 | 5.00 | 0.378 | 5.00 | 24.0 | * |
| 12.10.2023 | 58.70 | 8.27 | 5.00 | 0.453 | 5.00 | 24.0 | * |
| 13.10.2023 | 57.80 | 6.71 | 5.00 | 0.367 | 5.00 | 24.0 | * |
| 14.10.2023 | 59.30 | 7.34 | 5.00 | 0.413 | 5.00 | 24.0 | * |
| 15.10.2023 | 58.50 | 6.89 | 5.00 | 0.381 | 5.00 | 24.0 | * |
| 16.10.2023 | 59.70 | 6.54 | 5.00 | 0.363 | 5.00 | 24.0 | * |
| 17.10.2023 | 58.50 | 6.71 | 5.00 | 0.372 | 5.00 | 24.0 | * |
| 18.10.2023 | 58.00 | 6.72 | 5.00 | 0.369 | 5.00 | 24.0 | * |
| 19.10.2023 | 58.40 | 6.60 | 5.00 | 0.368 | 5.00 | 24.0 | * |
| 20.10.2023 | 58.00 | 6.60 | 5.00 | 0.364 | 5.00 | 24.0 | * |
| 21.10.2023 | 57.80 | 8.27 | 5.00 | 0.447 | 5.00 | 24.0 | * |
| 22.10.2023 | 56.60 | 7.41 | 5.00 | 0.397 | 5.00 | 24.0 | * |
| 23.10.2023 | 56.20 | 6.48 | 5.00 | 0.343 | 5.00 | 24.0 | * |
| 24.10.2023 | 55.10 | 6.48 | 5.00 | 0.336 | 5.00 | 24.0 | * |
| 25.10.2023 | 56.60 | 8.29 | 5.00 | 0.442 | 5.00 | 24.0 | * |
| 26.10.2023 | 57.90 | 7.21 | 5.00 | 0.399 | 5.00 | 24.0 | * |
| 27.10.2023 | 57.80 | 6.20 | 5.00 | 0.341 | 5.00 | 24.0 | * |
| 28.10.2023 | 58.70 | 9.44 | 5.00 | 0.529 | 5.00 | 24.0 | * |
| 29.10.2023 | 57.70 | 6.73 | 5.00 | 0.371 | 5.00 | 24.0 | * |
| 30.10.2023 | 57.80 | 6.35 | 5.00 | 0.353 | 5.00 | 24.0 | * |
| 31.10.2023 | 57.80 | 7.05 | 5.00 | 0.389 | 5.00 | 24.0 | * |
| Средние: | 57.64 | --- | 5.00 | --- | 5.00 | --- | |
| Итого: | --- | 213.65 | --- | 11.678 | --- | 744.0 | |

| Дата | M3 | Qo | BNP |
|------------|----------|---------|---------|
| | т | Гкал | ч |
| 30.09.2023 | 18058.84 | 879.199 | 58990.9 |
| 31.10.2023 | 18272.50 | 890.878 | 59734.8 |
| Итого: | 213.65 | 11.678 | 744.0 |

Представитель абонента

Представитель энергоснабжающей организации